WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 38111
Permit No.
Basin 44

NOTICE OF INTENT NO. 20373

1. OWNER CARL BETH
MAILING ADDRESS Ryndon Unit #166 Box 16
Elko, NV 89801

ADDRESS AT WELL LOCATION SE corner of W 6th Street & Buchanan Avenue

2. LOCATION SE ¼ SW ¼ Sec. 31 T 36 N/S R 57 E Elko County

PERMIT NO. (Issued by Water Resources) | 12-006-01-9 (Parcel No.) | Humboldt River Ranchos Unit 1 (Subdivision Name)

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[X] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top Soil		0	4	4
Sand, clay some gravel		4	15	11
Gravel sand some clay		15	20	5
Clay		20	95	75
Gravel	X	95	120	25
Brown clay		120	140	20

'92 MAR -6 AM 11:35
STATE ENGINEER

Date started February 26, 1992
Date completed March 2, 1992

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
Blow test	20		4

8. WELL CONSTRUCTION
Depth Drilled 140 Feet Depth Cased 140 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10-5/8 Inches	0 Feet	140 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6-5/8		.188	+1	140

Perforations:
Type perforation Mill slot
Size perforation 1/8 x 3
From 120 feet to 140 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [X] Pumped [X] Poured
Seal Type: [X] Neat Cement [X] Cement Grout [X] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 140 feet

9. WATER LEVEL
Static water level 45 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name HACKWORTH DRILLING, INC. (Contractor)
Address P.O. Box 850 (Contractor)
Elko, NV 89801
Nevada contractor's license number issued by the State Contractor's Board 020582
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1689
Signed David Hackworth
By driller performing actual drilling on site or contractor
Date 3-3-1992

(Rev. 3-91)

USE ADDITIONAL SHEETS IF NECESSARY

(O)-627