WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

DUAL COMPLETION
PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

PZ-92-4

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 38119
Permit No.
Basin 51

NOTICE OF INTENT NO. 19386

1. OWNER BARRICK GOLDSTRIKE
MAILING ADDRESS P.O. BOX 29
ELKO, NV 89801

ADDRESS AT WELL LOCATION
BARRICK GOLDSTRIKE MINE

2. LOCATION SE ¼ NW ¼ Sec. 30 T 36 N/S R 50 E EUREKA County
PERMIT NO. M/0441 (Issued by Water Resources) N/A (Parcel No.) N/A (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☒ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
SAND, GRAVEL, BOULDERS		0	35	35
WEATHERED LIMESTONES		35	225	190
WEATHERED DIONITE		225	250	25
DIONITE GRAY GREEN	WARM	250	980	730

92 APR 14 A9:51 STATE ENGINEER'S OFFICE

Date started MARCH 18, 19 92
Date completed MARCH 23, 19 92

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
100		

8. WELL CONSTRUCTION
Depth Drilled 980 Feet Depth Cased 980 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
12.25 Inches	0 Feet	35 Feet	
6.50 Inches	35 Feet	980 Feet	
Inches	Feet	Feet	

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
7.00	38	.500	0	35
1.25	2.25	.140	0	980
1.25	2.25	.140	0	640

Perforations:
Type perforation DRILLED HOLE
Size perforation 1/8"
From 1. 730 feet to 980 feet
From 2. 440 feet to 640 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 55'
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 1. 980-700 feet to 2. 640-420 feet

9. WATER LEVEL
Static water level 459 feet below land surface
Artesian flow N/A G.P.M. N/A P.S.I.
Water temperature 58 °F Quality GOOD

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name LANG EXPLORATORY DRILLING (Contractor)
Address 2286 W 1500 S SLC, UT 84104 (Contractor)

Nevada contractor's license number issued by the State Contractor's Board 0021976
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1410
Signed (By driller performing actual drilling on site or contractor)
Date MARCH 26, 1992

(Rev. 3-91)

USE ADDITIONAL SHEETS IF NECESSARY

(O)-627