WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 38125
Permit No. 57757
Basin 61

NOTICE OF INTENT NO. 18872

1. OWNER DEE GOLD MINING
MAILING ADDRESS P.O. BOX 1193
ELKO NV 89803

ADDRESS AT WELL LOCATION DEE GOLD MINE SITE

2. LOCATION NE ¼ NE ¼ Sec. 4 T 36 N/S R 49 E ELKO County
PERMIT NO. 57073T (Issued by Water Resources) N/A (Parcel No.) N/A (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☒ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☒ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
CLAY SOFT ROCK	500	0	600	600
HARD BLACK ROCK		600	1620	1020
BLACK FRACTURED		1620	1660	40

'92 APR 17 A10:20
STATE ENGINEER'S OFFICE

Date started FEBRUARY 18, 19 92
Date completed MARCH 25, 19 92

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 1660 Feet Depth Cased 1642 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
31	Inches	0	Feet	40	Feet
22	Inches	40	Feet	600	Feet
17½	Inches	600	Feet	1660	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
24	95	.375	0	40
18	71	.375	0	600
~~12~~	~~50~~	~~.375~~	~~0~~	~~1432~~
~~12~~	~~50~~	~~.375~~	~~1632~~	~~1642~~

Perforations:
Type perforation LOWERED
Size perforation 3/16 BY 2½
From 1432 feet to 1632 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50 FT.
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 1660 feet to 50 feet

9. WATER LEVEL
Static water level 450 feet below land surface
Artesian flow N/A G.P.M. N/A P.S.I.
Water temperature 118 °F Quality GOOD

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name LANG EXPLORATORY DRILLING (Contractor)
Address 2286 WEST 1500 SOUTH (Contractor)
SALT LAKE CITY UTAH 84104
Nevada contractor's license number issued by the State Contractor's Board 0021976
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1546T-1
Signed Rod Thompson (By driller performing actual drilling on site or contractor)
Date APRIL 10, 1992

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627