WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 38144
Permit No.
Basin 83

NOTICE OF INTENT NO. 18269

1. OWNER Louis B. Tassone
MAILING ADDRESS 2200 Schooner
Reno, Nv 89509

ADDRESS AT WELL LOCATION 2150 Cartwright
Block L Lot 2

2. LOCATION NE ¼ SE ¼ Sec. 31 T. 18 N/S R. 21 E Storey County
PERMIT NO. — (Issued by Water Resources) 3-091-01 (Parcel No.) Virginia City Highlands (Subdivision Name)

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[XX] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [XX] Rotary [ ] RVC
[X] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
OVERBURDEN		0	1	1
Rust colored & purple volcanic rock		1	8	7
Brown & tan & yellow volcanic rock & brown clay		8	23	15
Multi colored volcanic rock		23	33	10
Mostly purple w/ white spec & multicolored		33	50	17
Mostly purple white spec some green white spec		50	63	13
Purple white spec purple green white spec		63	76	13
Purple white spec green white spec little dark orange		76	180	104
Purple white spec little green white spec little bluish green white spec	X	180	208	28
oranish/ tan T.D. 239 ft		208	239	

Date started 3/12, 19 92
Date completed 3/16, 19 92

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [XX] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
20+		1 ½

8. WELL CONSTRUCTION
Depth Drilled 239 Feet Depth Cased 239 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From (Feet)	To (Feet)
10 5/8	0	58
8 ½	58	239

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	+ 2	239

Perforations:
Type perforation factory
Size perforation 3/32 X 3
From 199 feet to 219 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 51
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [ ] Cement Grout [XX] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 51 feet to 239 feet

9. WATER LEVEL
Static water level 151 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature cold °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Aqua Drilling & Well Service, Inc (Contractor)
Address 625 Spice Islands Dr Suite L (Contractor)
Sparks, Nv 89431
Nevada contractor's license number issued by the State Contractor's Board 15291
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1804
Signed Roger M Thrall (By driller performing actual drilling on site or contractor)
Date Roger M. Thrall 3/20/92

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627