

OFFICE USE ONLY
 Log No. 38151
 Permit No. _____
 Basin 85
 NOTICE OF INTENT NO. 17592

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER STEPHAN & SANDRA MASSIC ADDRESS AT WELL LOCATION 565 Valle Verde
 MAILING ADDRESS 11890 Rocky Mtn Street Sparks, NV
Reno, NV 89506
 2. LOCATION SE 1/4 Sec 19 T 21N N/S R 21 F Washoe County
 PERMIT NO. 076-371-06 Spanish Springs
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Top soil		0	1	1
Volcanic boulder		1	3	2
Brown clay w/some gravel		3	68	65
Soft zone (NO WATER)		68	71	3
Brown sandy clay		71	180	109
Soft zone (app 3GPM)	X	180	190	10
Brown sandy clay		190	290	100
Granite sands with brown clay		290	380	90
Brown clay		380	386	6
Granite sands with brown clay		386	441	55
Brown volcanic rock		441	455	14
Broken black volcanic rock	X	455	490	45
Black volcanic rock		490	500	10

8. WELL CONSTRUCTION
 Depth Drilled 500 Feet Depth Cased 500 Feet
 HOLE DIAMETER (BIT SIZE)
 From To
10 Inches 0 Feet 50 Feet
8 5/8 Inches 50 Feet 500 Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	0	500

Perforations:
 Type perforation factory sawed slot
 Size perforation 3/32 x 3 x 5 around
 From 275 feet to 285 feet
 From 385 feet to 395 feet
 From 455 feet to 495 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout
 Depth of Seal 50
 Placement Method: Pumped
 Poured
 Gravel Packed: Yes No
 From 50 feet to 500 feet

9. WATER LEVEL
 Static water level 220 feet below land surface
 Artesian flow 30+ G.P.M. _____ P.S.I.
 Water temperature cold °F Quality clear

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Wayne Drilling, Inc.
 Contractor
 Address P.O. Box 12370, Reno, NV 89510
 Contractor

Date started 3-3-92, 19_____
 Date completed 3-6-92, 19_____
 STATE ENGINEER'S OFFICE
 92 MAR 16 P 2:18

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			

Nevada contractor's license number issued by the State Contractor's Board 22549
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 923
 Signed [Signature]
 By driller performing actual drilling on site or contractor
 Date March 11, 1992