WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 38158
Permit No.
Basin 91

NOTICE OF INTENT NO. 18538

1. OWNER Bart Jacka
MAILING ADDRESS P.O. Box 1290
Verdi, NV 89439

ADDRESS AT WELL LOCATION 650 Riverdale Circle
Verdi, NV 89439

2. LOCATION NE ¼ SE ¼ Sec. 7 T. 19N N/S R. 18 E. Washoe County
PERMIT NO. (Issued by Water Resources) 38-695-16 (Parcel No.) Riverdale Subdivision Unit 1 lot 16 blk C (Subdivision Name)

3. WORK PERFORMED
☐ New Well ☐ Replace ☒ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
After trying to drill the well, the gravel pack fell into the well from the annulus and after developing the well, we were able to increase the yield from about 10 gpm with sand, we yielded about 25-30 and clean water. The process during the work filled in the bottom 10 feet and the well is now 280 instead of 290 as drilled originally.				

Date started 3-23, 1992
Date completed 3-24, 1992

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
25-30	190	8

8. WELL CONSTRUCTION
Depth Drilled ____ Feet Depth Cased ____ Feet

HOLE DIAMETER (BIT SIZE)

	From	To
____ Inches	____ Feet	____ Feet
____ Inches	____ Feet	____ Feet
____ Inches	____ Feet	____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)

Perforations:
Type perforation
Size perforation
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet

Surface Seal: ☐ Yes ☐ No
Depth of Seal
Placement Method: ☐ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☐ Concrete Grout
Gravel Packed: ☐ Yes ☐ No
From ____ feet to ____ feet

9. WATER LEVEL
Static water level 75 feet below land surface
Artesian flow ____ G.P.M. ____ P.S.I.
Water temperature cold °F Quality unknown

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Welsco Drilling Corp. (Contractor)
Address P.O. Box 888 (Contractor)
Fallon, NV 89406
Nevada contractor's license number issued by the State Contractor's Board 11752
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 772
Signed [signature] (By driller performing actual drilling on site or contractor)
Date 3-24-'92

(Rev. 3 91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627