WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 38181
Permit No.
Basin 103

NOTICE OF INTENT NO.

1. OWNER Mark Day
MAILING ADDRESS 853 LA Fond Dayton NV.
ADDRESS AT WELL LOCATION 853 LaFond

2. LOCATION NE ¼ SE ¼ Sec. 25 T. 17 N/S R. 22 E. Storey County
PERMIT NO. Issued by Water Resources
Parcel No. 3-314-19
Subdivision Name Mark Twain Estates

3. WORK PERFORMED
☐ New Well ☑ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☑ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☑ Rotary ☐ RVC
☐ Air ☐ Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Boulders & Sand		0	40	40
Gravels		40	75	35
Black & Red obsidian		75	140	65
Clay & imbeded Gravels		140	185	45
Black & Red Obsidian w/ Clay seams	XX	185	240	55
Hard Obsidian		240	275	35
Hard broken	XXX	275	285	10
Rust Colored Obsidian		285	295	10
T.D. 295'				

Date started 2/27, 19 92
Date completed 3/6, 19 92

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☑ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
20+	10	2 hrs

8. WELL CONSTRUCTION
Depth Drilled 295 Feet Depth Cased 295' Feet

HOLE DIAMETER (BIT SIZE)

	From	To
13¾ Inches	0 Feet	50' Feet
9⅞ Inches	50 Feet	295' Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6⅝	13.03	.188	0	295'

Perforations:
Type perforation Mill slot
Size perforation 3½ x 3/32
From 255' feet to 295' feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 55'
Placement Method: ☐ Pumped ☑ Poured
Seal Type: ☑ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☑ Yes ☐ No
From 55' feet to 295' feet

9. WATER LEVEL
Static water level 180 feet below land surface
Artesian flow G.P.M. 20+ P.S.I.
Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name H & H Pump Co. Contractor
Address 5551 Hy 50 E #3 Contractor
Carson City NV.
Nevada contractor's license number issued by the State Contractor's Board 31839
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1674
Signed Joe Butts By driller performing actual drilling on site or contractor
Date 3/17/92

(Rev. 3-91)

USE ADDITIONAL SHEETS IF NECESSARY

(0)-627