



PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 17428

1. OWNER JOHN DECARLO ADDRESS AT WELL LOCATION
 MAILING ADDRESS GARDNERVILLE, NV 1087 CANAL DR.
GARDNERVILLE, NV
 2. LOCATION NE 1/4 SW 1/4 Sec 12 T. 12 N. R. 20 E. DOUGLAS County
 PERMIT NO. 23-222-01 PINENUT
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other MUD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
SANDY CLAY w/GRAVEL		0	8	8
SANDY CLAY		8	23	15
CLAY		23	32	9
SANDY CLAY w/GRAVEL		32	54	22
LARGE GRAVEL		54	62	8
SANDY CLAY w/GRAVEL		62	93	31
CLAY w/COARSE SAND		93	125	32
BASALT w/CLAY		125	138	13
CLAY		138	220	82
COARSE SAND	✓	220	228	8
CLAY		228	231	3
COARSE SAND	✓	231	241	10
CLAY		241	250	9

'92 MAR 25 AM 11:00
 STATE ENGINEERS OFF.

8. WELL CONSTRUCTION
 Depth Drilled 250 Feet Depth Cased 250 Feet
 HOLE DIAMETER (BIT SIZE)
 From 10 5/8 Inches To 0 Feet 250 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>17</u>	<u>.188</u>	<u>0</u>	<u>250</u>

 Perforations:
 Type perforation FACTORY SLOT, SINGLE
 Size perforation 3" x 3/32"
 From 220 feet to 240 feet
 From _____ feet to _____ feet
 Surface Seal: Yes No Seal Type:
 Depth of Seal 50' Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 50 feet to 250 feet

9. WATER LEVEL
 Static water level 140 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature COLD °F Quality GOOD

Date started 3-2 19 92
 Date completed 3-6 19 92

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>AIR</u>	<u>20+</u>	<u>1</u>

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name EDDCO EXPLORATION, INC Contractor
 Address 7780 CURRY RD. Contractor
FALCON, NV 89406
 Nevada contractor's license number issued by the State Contractor's Board 27673
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1726
 Signed Paul J. Moore
 By driller performing actual drilling on site or contractor
 Date 3-6-92