WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 38186
Permit No.
Basin 105

NOTICE OF INTENT NO. 19724

1. OWNER PAINTER CONSTRUCTION
MAILING ADDRESS P.O. BOX 37
GENOA, NEVADA

ADDRESS AT WELL LOCATION NOT ASSIGNED YET

2. LOCATION ~~SW/VE~~ ~~SESW~~ ¼ Sec ~~34~~ 35 T 13 N/S R 20 E Douglas County

PERMIT NO. 49432 (Issued by Water Resources) 23-260-64 (Parcel No.) Brentwood Development #1 (Subdivision Name)

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[X] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [ ] Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sandstone w/cobbles		0	4	4
Gravels, loose		4	85	81
Clay, tight		85	100	15
Gravels carruing water		100	118	18
Clay seam, hard		118	123	5
Water bearing gravels		123	140	17
TD: 140 ft				
Well capacity: 35 plus GPM				

Date started March 23, 19 92
Date completed March 25, 19 92

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
Developed with air, blew for 3 hours		

8. WELL CONSTRUCTION
Depth Drilled 140 Feet Depth Cased 140 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
12 Inches	0 Feet	100 Feet	
9 3/4 Inches	100 Feet	140 Feet	
Inches	Feet	Feet	

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13.3	.188	0	140

Perforations:
Type perforation Factory Mill Slots
Size perforation 3" x 3/32"
From 120 feet to 140 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 103
Placement Method: [X] Pumped [ ] Poured
Seal Type: [X] Neat Cement [ ] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 103 feet to 140 feet

9. WATER LEVEL
Static water level 25 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature cold °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name A & H PUMP CO. (Contractor)
Address 5551 Hiway 50 E #3 (Contractor)
Carson City, NV 89701
Nevada contractor's license number issued by the State Contractor's Board 31839
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1674
Signed Joe Butts (By driller performing actual drilling on site or contractor)
Date 3/25/92

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627