

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 10823

1. OWNER PAINTER CONSTRUCTION ADDRESS AT WELL LOCATION None assigned as yet.
 MAILING ADDRESS P.O. BOX 37
GENOA, NEVADA

2. LOCATION SW SE 1/4 SW 1/4 Sec 35 T. 13 N/S R. 20 E Douglas County
 PERMIT NO. 49133 23-260-64 Brentwood Development # 1
Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other.....

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Hard sandstone w/ small cobbles		0	5	5
Gravels to 1/4"		5	20	15
Small gravles		20	25	5
Clay with sand lens		25	35	10
Small gravles with clay seams		35	50	15
Cobbles		50	80	30
Clay, medium to tight		80	110	30
Gravels w/ water	xx	110	120	10
1/4" gravles with clay seams	xx	120	150	30
T.D. 150 ft				
Capacity: 40 plus GPM				

8. WELL CONSTRUCTION
 Depth Drilled 150 Feet Depth Cased 150 Feet

HOLE DIAMETER (BIT SIZE)
 From To
12 Inches 0 Feet 100 Feet
9 3/4 Inches 100 Feet 150 Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13.3	.188	0	150

Perforations:
 Type perforation Factory slotted
 Size perforation 3" x 3/32"
 From 130 feet to 150 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 104 Neat Cement
 Cement Grout
 Placement Method: Pumped Concrete Grout
 Poured

Gravel Packed: Yes No
 From 104 feet to 150 feet

9. WATER LEVEL
 Static water level 15 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature cold °F Quality good

Date started March 18 1992
 Date completed March 20 1992

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift			
Developed well with air. Blew of 2 hours			

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name A & H PUMP CO.
 Contractor
 Address 5551 Hiway 50 E, #3
Carson City, NV 89701
 Contractor

Nevada contractor's license number issued by the State Contractor's Board 31839
 Nevada driller's license number issued by the Division of Water Resources, on-site driller 1674

Signed Joe Curtis
 By driller performing actual drilling on site or contractor
 Date 3/25/92