

OFFICE USE ONLY
 Log No. 38195
 Permit No. _____
 Basin 105

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 19425

1. OWNER JERRY PALMER ADDRESS AT WELL LOCATION 2758 E SAW GARDNERVILLE, NV
 MAILING ADDRESS 2758 E SAW GARDNERVILLE, NV

2. LOCATION NW 1/4 NW 1/4 Sec. 35 T. 14 N. R. 20 E. DOUGLAS County DOUGLAS
 PERMIT NO. _____ Parcel No. 21-250-12 Subdivision Name JOHNSON LAKE
 Issued by Water Resources

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
CLAY		220	223	3
SANDY CLAY		223	239	16
SAND	✓	239	251	12
SANDY CLAY		251	264	13
CLAY		264	270	6+

8. WELL CONSTRUCTION
 Depth Drilled 270 Feet Depth Cased 270 Feet

HOLE DIAMETER (BIT SIZE)
 From To
5 7/8 Inches 220 Feet 270 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>5 7/16</u>	<u>11</u>	<u>1.88</u>	<u>220</u>	<u>270</u>

Perforations:
 Type perforation FACTORY SET, SINGLE
 Size perforation 3 X 3/32
 From 270 feet to 260 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type: N/A
 Neat Cement
 Cement Grout
 Concrete Grout

Depth of Seal _____
 Placement Method: Pumped Poured
 Gravel Packed: Yes No
 From _____ feet to _____ feet

9. WATER LEVEL
 Static water level 140 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature COLD °F Quality GOOD

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name EDDIE EXPLORATION, INC. Contractor
 Address 7780 CORRY RD. FALLON, NV Contractor
 Nevada contractor's license number issued by the State Contractor's Board 27613
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1726
 Signed Paul J. Murray
 By driller performing actual drilling on site or contractor
 Date 3-12-92

Date started 3-11 1992
 Date completed 3-12 1992

7. WELL TEST DATA

TEST METHOD: Bailor Pump Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>AIR</u>	<u>15+</u>	<u>-</u>	<u>3</u>

'92 MAR 25 AM 059
 STATE ENGINEERS OFFICE