

OFFICE USE ONLY  
 Log No. 38197  
 Permit No. \_\_\_\_\_  
 Basin 108  
 NOTICE OF INTENT NO. 17424

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT  
 Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER DONALD FEUTIMAN ADDRESS AT WELL LOCATION 46 S. RYBEE LN YERINGTON  
 MAILING ADDRESS SUN VALLEY, NV  
 2. LOCATION SE 1/4 SE 1/4 Sec 2 T 13 N3 R 26 E LYON County  
 PERMIT NO. 14-652-14 Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_  
 Issued by Water Resources

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other MVD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
SANDY CLAY		0	12	12
CLAY		12	16	4
SANDY CLAY		16	35	19
CLAY		35	120	85
SANDY CLAY		120	148	28
CLAY		148	157	9
SANDY CLAY		157	169	12
CLAY		169	190	21
SANDY CLAY		190	194	4
CLAY		194	211	17
SANDY CLAY		211	272	61
FRACTURED SHALE	✓	272	300	28

8. WELL CONSTRUCTION  
 Depth Drilled 300 Feet Depth Casd 300 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From To  
10 3/8 Inches 0 Feet 300 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 3/8</u>	<u>17</u>	<u>.188</u>	<u>0</u>	<u>300</u>

Perforations:  
 Type perforation FACTORY SINGLE SLOTTED  
 Size perforation 3 x 3/32  
 From 280 feet to 300 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 50  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 50 feet to 300 feet

9. WATER LEVEL  
 Static water level 170 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature COOL °F Quality GOOD

Date started 3-24, 1992  
 Date completed 3-31, 1992

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input checked="" type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift			
AIR	9	—	1
PUMP	12	120	2

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name EDCO EXPLORATION INC. Contractor  
 Address 7780 CURRY RD. FAHON, NV 89406 Contractor  
 Nevada contractor's license number 27673 issued by the State Contractor's Board  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1726  
 Signed Paul J. Moore By driller performing actual drilling on site or contractor  
 Date 3-31-92