WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 38202
Permit No.
Basin 200

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 9680

1. OWNER Bill F. Bush or Carol Ashby
MAILING ADDRESS 213 Hancock St.
Las Vegas, Nev. 89110

ADDRESS AT WELL LOCATION Eagle Valley, Nev.

2. LOCATION SE ¼ SW ¼ Sec. 35 T. 2 N/S R. 69 E. East Lincoln County
PERMIT NO. Single family (Issued by Water Resources) | 8 (Parcel No.) | N/A (Subdivision Name)

3. TYPE OF WORK
New Well ☑ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☑ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☑
Other ☐

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| Clay & Cobbles | – | 0 | 70 | 70 |
| Bed Rock basaults | – | 70 | 140 | 70 |
| Broken Bed Rock | W | 140 | 160 | 20 |
| Bedrock Sm. Cracks | W | 160 | 203 | 43 |

RECEIVED 92 APR -3 A10:55 STATE ENGINEERS OFFICE

Date started March 22, 1992
Date completed March 27, 1992

7. WELL TEST DATA

| Pump RPM | G.P.M. | Draw Down | After Hours Pump |
|---|---|---|---|
| N/A | | | |

BAILER TEST
G.P.M. N/A Draw down ..... feet ..... hours
G.P.M. Draw down ..... feet ..... hours
G.P.M. Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter 10 inches Total depth 203 feet
..... inches
..... inches
Casing record New
Weight per foot 14.97 Thickness .219

| Diameter | From | To |
|---|---|---|
| 6 5/8 inches | 1' above feet | 203 feet |
| inches | feet | feet |
| inches | feet | feet |
| inches | feet | feet |
| inches | feet | feet |
| inches | feet | feet |

Surface seal: Yes ☑ No ☐ Type Concrete grout
Depth of seal 100' feet
Gravel packed: Yes ☑ No ☐
Gravel packed from 100 feet to 203 feet

Perforations:
Type perforation Mill Tourch
Size perforation 5/32 x 2½ 5/32 x 6
From 140 feet to 160 feet
From 160 feet to 203 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 105 feet below land surface
Flow N/A G.P.M. N/A P.S.I.
Water temperature Cold °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Gardner Drilling (Contractor)
Address Box 18 New Castle, Ut. 84756 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 31759
Nevada contractor's driller's number issued by the Division of Water Resources 1710
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1710
Signed Dale Gardner (By driller performing actual drilling on site or contractor)
Date April 1, 1992

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627