MW-2

WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 38224
Permit No.
Basin 4-64

I

NOTICE OF INTENT NO. 16053

1. OWNER NDEP 91-LA01
MAILING ADDRESS 123 W. Nye Lane
Carson City, NV 89710

ADDRESS AT WELL LOCATION Pete's Garage
Front Street 1/4 mile west of Eastgate
Battle Mtn., Nevada

2. LOCATION NE 1/4 SE 1/4 Sec. 18 T 32 N/S R 45 E Lander County

PERMIT NO. M/O-521 (Issued by Water Resources) | Parcel No. | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☒ Other Auger

6. LITHOLOGIC LOG MW-2

Material	Water Strata	From	To	Thickness
Silty Clay	No	0	6 1/2	6 1/2
Sandy gravel	Yes	6 1/2	13	6 1/2
Gravelly clay	Yes	13	16	3
Fine Sand	Yes	16	20	4

RECEIVED
STATE ENGINEER'S OFFICE
92 MAY 22 P2:11

Date started 3-10, 1992
Date completed 3-10, 1992

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
N/A		

8. WELL CONSTRUCTION
Depth Drilled 20 Feet Depth Cased 18 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 Inches		0 Feet	20 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4	Sch 40		3 1/2	1/2

Perforations:
Type perforation Slotted
Size perforation 0.020-inch
From 18 1/2 feet to 3 1/2 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 3 1/2 to 0
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 18 1/2 feet to 3 0 feet

9. WATER LEVEL
Static water level 6 feet below land surface
Artesian flow N/A G.P.M. N/A P.S.I.
Water temperature N/A °F Quality N/A

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name [signature]
Address 1635 Bellevue Rd. Contractor
RENO NEV. 89509 Contractor
Nevada contractor's license number issued by the State Contractor's Board
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1028
Signed [signature] By driller performing actual drilling on site or contractor
Date 5/19/92

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627