

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.370 and NAC 534.340

Log No. 38248
 Permit No. 56525
 Basin 212

NOTICE OF INTENT NO. 3929

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

1. OWNER Jerry Eldridge ADDRESS AT WELL LOCATION N/A
 MAILING ADDRESS 3815 Torino Avenue
Las Vegas, Nevada 89118

2. LOCATION NE 1/4 SE 1/4 Sec. 18 T. 22S N/S R. 61 E Clark County
 PERMIT NO. 56525
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary
 Other _____

6. LITHOLOGIC LAB

Material	Water Strata	From	To	Thickness
Gravel		0	4	
Cemented Gravel		4	9	
Clay & Gravel		9	22	
Cemented Gravel		22	24	
Clay & Gravel		24	38	
Cemented Gravel		38	40	
Clay & Gravel		40	60	
Boulders		60	72	
Clay Gravel		72	185	
Cemented Gravel		185	220	
Clay Gravel		220	260	
Gravel & Water	x	260	270	
Clay Gravel		270	355	
Gravel & Water	x	355	360	
Cemented Gravel		360	365	
Gravel & Water	x	365	375	

8. WELL CONSTRUCTION
 Total Depth 375 Feet
 HOLE DIAMETER (BIT SIZE)
 From To
12 1/4 Inches 0 Feet 55 Feet
9 7/8" Inches 55 Feet 375 Feet
 _____ Inches _____ Feet _____ Feet
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>8 5/8"</u>	<u>16.94</u>	<u>.188</u>	<u>+1</u>	<u>375</u>

 Factory Perforations 8 row 3/16
335-355Ft.
 Surface Seal: Yes No Seal Type:
 Depth of Seal 55 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From _____ Feet to _____ Feet

RECEIVED
 FEB 07 1992
 Div. of Water Resources
 Branch Office - Las Vegas, NV

Date started 1-15, 1992
 Date completed 1-24, 1992

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			

9. WATER LEVEL
 Static water level 240 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Vernon H. Dimick
 Contractor

Address 7115 Rogers St.
 Contractor
Las Vegas, Nevada 89118

Nevada contractor's license number issued by the State Contractor's Board 10062
 Nevada contractor's driller's number issued by the Division of Water Resources 552
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 552
 Signed V. H. Dimick
 By driller performing actual drilling on site or contractor
 Date January 27, 1992