WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 38268
Permit No.
Basin 101

NOTICE OF INTENT NO. 20590

1. OWNER Paul Landry
MAILING ADDRESS 977 E. Stanley Blvd #188
Livermore, Calif. 94550

ADDRESS AT WELL LOCATION
1552 Solias Road
Fallon, Nev. 89406

2. LOCATION SW ¼ NW ¼ Sec. 22 T. 18 N/S R. 28 E. Churchill County
PERMIT NO. (Issued by Water Resources) 06-433-52 (Parcel No.) Jack Barnes Parcel Map (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Coarse Sand		0	18	18
Brown Clay		18	20	2
Gray Clay		20	23	3
Gray Sand		23	30	7
Black Clay		30	35	5
Greenish Gray Sand		35	38	3
Gray Clay		38	42	4
Brown Clay		42	43	1
Coarse Sand		43	55	12
Brown Clay		55	60	5
Coarse Sand	X	60	71	11
Green Clay		71	72	1

'92 AUG 10 P1:21
STATE ENGINEER'S OFFICE

Date started July 21, 19 92
Date completed July 21, 19 92

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 72 Feet Depth Cased 72 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 Inches		0 Feet	72 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6-5/8	12.92	.188	0	72

Perforations:
Type perforation Mill Cut
Size perforation 1/8"
From 63 feet to 71 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50'
Placement Method: ☒ Pumped ☐ Poured

Seal Type:
☒ Neat Cement
☐ Cement Grout
☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 72 feet

9. WATER LEVEL
Static water level 5 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cool °F Quality Unknown

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name PARSONS DRILLING, INC. (Contractor)
Address P.O. BOX 1265 (Contractor)
FALLON, NEVADA 89407-1265
Nevada contractor's license number issued by the State Contractor's Board 29064
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1753
Signed Wayne Parsons (By driller performing actual drilling on site or contractor)
Date July 28, 1992

(Rev. 3-91)

USE ADDITIONAL SHEETS IF NECESSARY

(O)-627