WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 38781
Permit No.
Basin 101

NOTICE OF INTENT NO. 20587

1. OWNER Mary Booth
MAILING ADDRESS P.O. Box 261
Fallon, NEv. 89407-0261

ADDRESS AT WELL LOCATION 3580 Hillsboro Dr.
Fallon, Nev. 89406

2. LOCATION N/N ¼ N/N ¼ Sec. 15 T. 19 N/S R. 28 E. Churchill County
PERMIT NO. (Issued by Water Resources) 8-031-29 (Parcel No.) (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand		0	8	8
Sandy Clay		8	15	7
Brown Coarse Sand		15	17	2
Brown Clay		17	28	11
Brown Coarse Sand		28	34	6
Brown Clay		34	38	4
Brown Coarse Sand		38	43	7
Fine Sand		43	48	5
Black & Brown Coarse Sand	X	48	55	7

'92 AUG 12 A10:07
STATE ENGINEER'S OFFICE

Date started August 3, 19 92
Date completed August 3, 19 92

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 55 Feet Depth Cased 55 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 Inches	0 Feet	55 Feet	
Inches	Feet	Feet	
Inches	Feet	Feet	

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6-5/8	12.92	.188	0	55

Perforations:
Type perforation Mill Cut
Size perforation 1/8"
From 50 feet to 53 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 25'
Placement Method: ☒ Pumped ☐ Poured

Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 25 feet to 55 feet

9. WATER LEVEL
Static water level 13' 4" feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cool °F Quality Unknown

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name PARSONS DRILLING, INC. (Contractor)
Address P.O. BOX 1265 (Contractor)
Fallon, Nev. 89407-1265
Nevada contractor's license number issued by the State Contractor's Board 29064
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1715
Signed Doug Parsons (By driller performing actual drilling on site or contractor)
Date Aug. 5, 1992

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O) 627