

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 3030 Holly Ave, SILVER SPRINGS NV, 89429

1. OWNER Richard Cervie ADDRESS AT WELL LOCATION 3030 Holly Ave, SILVER SPRINGS NV, 89429
 MAILING ADDRESS 3030 Holly Ave, SILVER SPRINGS, NV, 89429
 2. LOCATION SW 1/4 SW 1/4 Sec 4 T. 17 N/S R. 25 E L40N County LYON
 PERMIT NO. NA 17-117-01 LAKEVIEW NO. 13
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other MUD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>Silty SAND AND HARD STREAKS</u>		<u>0</u>	<u>18-6</u>	<u>18-6"</u>
<u>TAN clay</u>		<u>18-6</u>	<u>72'</u>	<u>53-6"</u>
<u>TAN clay + SILT</u>		<u>72'</u>	<u>96'</u>	<u>24</u>
<u>COURSE SAND AND GRAVEL</u>	<u>←</u>	<u>96</u>	<u>117</u>	<u>21</u>
<u>TAN clay</u>		<u>117</u>	<u>120'</u>	<u>3</u>

92 JUL 28 10:52 STATE ENGINEERS OFFICE

8. WELL CONSTRUCTION
 Depth Drilled 120 Feet Depth Cased 121 Feet
 HOLE DIAMETER (BIT SIZE)
 From 10 5/8 Inches To 120 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>13.00</u>	<u>188</u>	<u>+1</u>	<u>120</u>

Perforations:
 Type perforation Torch Cut
 Size perforation 1/8 x 6" 6 ROWS
 From 100' feet to 120' feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 Surface Seal: Yes No Seal Type:
 Depth of Seal 50' Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 50 feet to 120' feet

9. WATER LEVEL
 Static water level 35 feet below land surface
 Artesian flow NA G.P.M. NA P.S.I.
 Water temperature Cold °F Quality CLEAR

Date started 7/13, 19 92
 Date completed 7/16, 19 92

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>75</u>	<u>100'</u>	<u>4 Hrs.</u>

pump with pump 20 Gallons per min. with 5 ft Draw Down. 4 Hrs

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Leach Drilling Inc Contractor
 Address P.O. Box 599 Contractor
Silver Springs NV, 89429
 Nevada contractor's license number issued by the State Contractor's Board 031841
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1740
 Signed Mathew D. Leach
 By driller performing actual drilling on site or contractor
 Date 7/18/92