

OFFICE USE ONLY  
 Log No. 38309  
 Permit No. \_\_\_\_\_  
 Basin. 108

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. \_\_\_\_\_

1. OWNER DAN BARBER ADDRESS AT WELL LOCATION YEARINGTON NV.  
 MAILING ADDRESS 138 NORTH HWY 95  
YEARINGTON NV. 89447  
 2. LOCATION NE 1/4 SE 1/4 Sec. 29 T. 14 N/S R. 25 E LYON County  
 PERMIT NO. 14-271-09 Issued by Water Resources Parcel No. \_\_\_\_\_ Subdivision Name NA

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Sandy Dirt		0	18	18
GRAVEL & SAND		18	43	25
Brown clay with some clay		43	62	19
COURSE SAND & SILT		62	73	11
Light Brown clay & silt		73	109	36
SAND	✓	109	131	22
SAND & GRAVEL	✓	131	150	19

8. WELL CONSTRUCTION  
 Depth Drilled 150' Feet Depth Cased 151' Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 10 5/8 Inches To 150' Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet  
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>13.00</u>	<u>1.88</u>	<u>+1</u>	<u>150'</u>

Perforations:  
 Type perforation 1/8 Torch Cut  
 Size perforation 1/8 x 6" 6 ROWS  
 From 130' feet to 150' feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 60'  Neat Cement  
 Placement Method:  Pumped  Concrete Grout  
 Poured  
 Gravel Packed:  Yes  No  
 From 60' feet to 150' feet

9. WATER LEVEL  
 Static water level 45 1/2 feet below land surface  
 Artesian flow NA G.P.M. 50  
 Water temperature Cold °F Quality Clear

Date started 6/1/92 1992  
 Date completed 6/27 1992

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>air</u>	<u>50</u>	<u>from 130 feet</u>	
<u>for 3 hrs.</u>			
<u>pumped 20 GPM 2 hrs</u>			
<u>with 5 feet draw down</u>			

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Leach Drilling Inc. Contractor  
 Address P.O. Box 599 Contractor  
Silver Springs NV. 89429  
 Nevada contractor's license number issued by the State Contractor's Board 31848  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1740  
 Signed Nathaniel K. Leach  
 By driller performing actual drilling on site or contractor  
 Date 7/24/92