

OFFICE USE ONLY
 Log No. 38314
 Permit No. _____
 Basin 44
 NOTICE OF INTENT NO. 99204

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER Randy & Rhonda Porter ADDRESS AT WELL LOCATION Lot 6, Blk 5, Subdiv. 1, Humboldt North on Hillside from 11th St. west side of street
 MAILING ADDRESS 420 Sunset Ave #48 Elko NV 89801

2. LOCATION Sec. 14, T. 31, R. 57, E. 11th County Humboldt
 PERMIT NO. 2-005-012 Parcel No. _____ Subdivision Name Ranches
Issued by Water Resources

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>200M</u>		<u>0</u>	<u>4</u>	<u>4</u>
<u>Clay</u>		<u>4</u>	<u>28</u>	<u>24</u>
<u>SANDSTONE</u>		<u>28</u>	<u>92</u>	<u>64</u>
<u>Clay</u>		<u>92</u>	<u>98</u>	<u>6</u>
<u>SANDSTONE</u>		<u>98</u>	<u>103</u>	<u>5</u>
<u>Clay</u>		<u>103</u>	<u>101</u>	<u>58</u>
<u>Small gravel</u>	<u>Gravel</u>	<u>101</u>	<u>120</u>	<u>19</u>
<u>Small 1/4" gravel</u>				

8. WELL CONSTRUCTION
 Depth Drilled 170 Feet Depth Cased 170 Feet

HOLE DIAMETER (BIT SIZE)
 From _____ To _____
10 Inches 0 Feet 120 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6"</u>	<u>7</u>	<u>1.88</u>	<u>12</u>	<u>170</u>

Perforations:
 Type perforation slots
 Size perforation 7/16" x 3"
 From 150 feet to 170 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 58 Neat Cement
 Placement Method: Pumped Concrete Grout
 Poured

Gravel Packed: Yes No
 From 58 feet to 170 feet

9. WATER LEVEL
 Static water level 64 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature 60.4 °F Quality Good

Date started 2-28, 1992
 Date completed 2-29, 1992

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>31</u>		<u>4</u>

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Feutig Drilling Co Contractor
 Address PO Box 525 Elko NV 89801 Contractor
 Nevada contractor's license number issued by the State Contractor's Board 0031904
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1584
 Signed Shouk Feutig
 By driller performing actual drilling on site or contractor
 Date 3-2-92

92 MAR -3 AM 100
 STATE ENGINEERS OFFICE