

OFFICE USE ONLY  
 Log No. 30319  
 Permit No. \_\_\_\_\_  
 Basin 45

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 15304

1. OWNER Leeward Singer ADDRESS AT WELL LOCATION 6 ST WEST  
 MAILING ADDRESS 382 Juniper ST END SOUTH side Lot 3 Block 61  
Elko N.V. 89803 Unit 5 Kirtledge CYN  
 2. LOCATION SW 1/4 SW 1/4 Sec. 35 T. 35 N/S R 56 E Elko County  
 PERMIT NO. 37-061-03-3 Meadow Valley Rancho Subdivision Name  
 Issued by Water Resources Parcel No.

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Cemented Gravel		0	8'	8'
Cemented SANDSTONE		8'	38'	30'
Brown Clay		38'	42'	4'
Cemented SAND & Gravel		42'	182'	140'
Brown Clay		182'	196'	14'
Loose Gravel		196'	198'	2'
Cemented SAND & Gravel		198'	220'	22'
Loose Gravel	water	220'	224'	4'
Cemented SAND & Gravel		224'	268'	44'
Loose Gravel	water	268'	300'	32'

8. WELL CONSTRUCTION  
 Depth Drilled 300 Feet Depth Cased 300 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From To  
10" Inches 0 Feet 65 Feet  
9" Inches 65 Feet 300 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6"</u>	<u>12.92</u>	<u>188</u>	<u>12</u>	<u>300</u>

Perforations:  
 Type perforation slots  
 Size perforation 3/16" - 3/8"  
 From 260 feet to 300 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 65'  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 65 feet to 300 feet

9. WATER LEVEL  
 Static water level 220 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature cold °F Quality Good

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Fertig Drilling Co Contractor  
 Address PO Box 525 Contractor  
Elko N.V. 89803  
 Nevada contractor's license number issued by the State Contractor's Board 31904  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1584  
 Signed Shouk c Fertig Jr  
 By driller performing actual drilling on site or contractor  
 Date 7-28-92

Date started 7-10- 1992  
 Date completed 7-20 1992

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>32</u>		<u>6 hrs</u>

92 AUG 10 P 1 31  
 RECEIVED  
 STATE ENGINEERS OFFICE