WHITE--DIVISION OF WATER RESOURCES
CANARY--CLIENT'S COPY
PINK--WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 38340
Permit No.
Basin 85

NOTICE OF INTENT NO. 20112

1. OWNER PAUL & KIMBERLY OLSON
MAILING ADDRESS 1353 Boysey Dr.
San Jose, CA. 95118

ADDRESS AT WELL LOCATION
35 Rodgers Ranch Road
Sparks, NV

2. LOCATION SW ¼ SW ¼ NW ¼ Sec. 20 T. 21N N/S R. 21 E. Washoe County

PERMIT NO. (Issued by Water Resources) | 76-690-01 (Parcel No.) | Spanish Springs (Subdivision Name)

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[X] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top soil		0	1	1
Brown clay		1	6	5
Volcanic boulder		6	9	3
Brown clay		9	53	44
Soft zone (NO WATER)		53	55	2
Brown clay w/volcanic gravels		55	119	64
Soft zone (NO WATER)		119	121	2
Brown clay w/granite & volcanic sands		121	216	95
Soft zone (app 3 GPM)	X	216	219	3
Brown sandy clay		219	259	40
Brown clay w/granite sands		259	319	60
Granite cemented sands some clay streaks		319	365	44
Brown sandy clay		365	430	65
Black volcanic rock		430	440	10
BRown volcanic rock		440	455	5
Fractured black volcanic rock	X	455	493	38
Black volcanic rock		493	500	7

Date started 8-3-92, 19
Date completed 8-6-92, 19

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

STATE OF NEVADA
AUG 19 '92 10:52

8. WELL CONSTRUCTION
Depth Drilled 500 Feet Depth Cased 500 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 Inches		0 Feet	50 Feet
8 5/8 Inches		50 Feet	500 Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		.188	0	500

Perforations:
Type perforation factory sawed slot
Size perforation 3/32 x 3 x 5 around
From 435 feet to 495 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [ ] Pumped [X] Poured

Seal Type:
[ ] Neat Cement
[X] Cement Grout
[ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 500 feet

9. WATER LEVEL
Static water level 223 feet below land surface
Artesian flow 15 G.P.M. P.S.I.
Water temperature cold °F Quality clear

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Wayne Drilling, Inc. (Contractor)
Address P.O. Box 12370 (Contractor)
Reno, NV 89510

Nevada contractor's license number issued by the State Contractor's Board 22549

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 923

Signed Gary C. Hafman
(By driller performing actual drilling on site or contractor)

Date August 15, 1992

(Rev. 3-91)

USE ADDITIONAL SHEETS IF NECESSARY

(O)-627