WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 38241
Permit No.
Basin 86

NOTICE OF INTENT NO. 27637

1. OWNER HELEN RANEY
MAILING ADDRESS 5555 Wainscott Drive
Sparks, NV 89431

ADDRESS AT WELL LOCATION 5535 Wainscott Drive
Sparks, NV 89431

2. LOCATION SE ¼ SE ¼ Sec. 13 T. 20N N/S R. 19 E. Washoe County
PERMIT NO. (Issued by Water Resources) 082-473-18 (Parcel No.) Sun Valley (Subdivision Name)

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[X] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top soil		0	1	1
BRown clay		1	16	15
Yellow Clay		16	42	26
Brown clay		42	90	48
Gray volcanic rock		90	111	21
FRacture volcanic rock	X	111	131	20
Gray volcanic rock		131	140	9

'92 AUG 26 A11:41
STATE ENGINEER

Date started 8-19-92, 19
Date completed 8-20-92, 19

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 140 Feet Depth Cased 140 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From Feet	To Feet
10	0	50
8 5/8	50	140

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		.188	0	140

Perforations:
Type perforation factory sawed slot
Size perforation 3/32 x 3 x 5 around
From 95 feet to 135 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [ ] Pumped [X] Poured

Seal Type: [ ] Neat Cement [X] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 140 feet

9. WATER LEVEL
Static water level 73 feet below land surface
Artesian flow 60+ G.P.M. P.S.I.
Water temperature cold °F Quality clear

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Wayne Drilling, Inc. (Contractor)
Address P.O. Box 12370 (Contractor)
Reno, NV 89510
Nevada contractor's license number issued by the State Contractor's Board 22549
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 923
Signed [signature] (By driller performing actual drilling on site or contractor)
Date August 22, 1992

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O) 627