

STATE OF NEVADA
 DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
 Log No. 38343
 Permit No. 07
 Basin 07
 NOTICE OF PATENT NO. 16389

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER Reno Sparks Convention & Vistors Aut. ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS Post Office Box 837 _____
Reno, Nevada 89504-0837 _____
 2. LOCATION NW 1/4 NE 1/4 Sec. 32 T. 20 N/S R. 20 E Washoe County _____
 PERMIT NO. W-302B _____
 Issued by Water Resources Parcel No. _____
 Wildcreek Golf Course _____
 Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Dirt, Silt, Clay, Sm/Lg Gravels, Sand		0	9	9
Broken Rock, Sands, Gravels		9	120	111
Consolidated Rock		120	140	20
Consolidated Rock-Fractures		140	200	60
Black Lava Rock, Small Fractures		200	360	160
Black Lava Rock		360	403	43
WELL ABANDONED TO FULL DEPTH WITH HOLE PLUG AND CYPAN - VISCOCITY 90 SECONDS WEIGHT 10.33				

8. WELL CONSTRUCTION
 Depth Drilled 403 Feet Depth Cased _____ Feet
 HOLE DIAMETER (BIT SIZE)
 From _____ To _____
8 Inches 0 Feet 403 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)

Perforations:
 Type perforation _____
 Size perforation _____
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 75 Neat Cement
 Cement Grout
 Placement Method: Pumped Poured Concrete Grout
 Gravel Packed: Yes No
 From _____ feet to _____ feet

9. WATER LEVEL
 Static water level 15 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Sargent Drilling, Inc. Contractor
 Address 9955 North Virginia Street Contractor
Reno, Nevada 89506
 Nevada contractor's license number issued by the State Contractor's Board 26917
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1482
 Signed Dan Prange
 By driller performing actual drilling on site or contractor
 Date August 20, 1992

7. WELL TEST DATA

TEST METHOD:	Bailer	Pump	Air Lift
	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)	