WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 38347
Permit No.
Basin 92A

NOTICE OF INTENT NO. 71630

1. OWNER MEL EVENS/AWARD, INC.
MAILING ADDRESS P.O. Box 60515
Reno, NV 89506

ADDRESS AT WELL LOCATION
10800 Plata Mesa
Reno, NV 89506

2. LOCATION SW¼ NE ¼ Sec. 25 T. 21N N/S R. 18 E. Washoe County
PERMIT NO. (Issued by Water Resources) 086-174-14 (Parcel No.) Silver Knolls (Subdivision Name)

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[X] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top soil		0	1	1
Brown sandy clay		1	69	68
Soft zone (fine brown sand)		69	73	4
Brown sandy clay		73	91	18
Soft zone	X	91	97	6
Brown soft sandy clay		97	123	26
Coarse sand	X	123	141	18
Brown clay		141	146	5

'92 AUG 19 A10:53
STATE ENGINEER'S OFFICE

Date started 8-13-92, 19
Date completed 8-13-92, 19

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 146 Feet Depth Cased 146 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 Inches		0 Feet	50 Feet
6 5/8 Inches		50 Feet	146 Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		.188	0	146

Perforations:
Type perforation factory sawed slot
Size perforation 3/32 x 3 x 5 around
From 120 feet to 140 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [X] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 146 feet

9. WATER LEVEL
Static water level 67 feet below land surface
Artesian flow 20 G.P.M. P.S.I.
Water temperature cold °F Quality clear

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Wayne Drilling, Inc. (Contractor)
Address PO Box 12370 (Contractor)
Reno, NV 89510
Nevada contractor's license number issued by the State Contractor's Board 22549
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 923
Signed [signature] (By driller performing actual drilling on site or contractor)
Date August 15, 1992

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627