


PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340



1. OWNER BILL & SHELLY CLARK ADDRESS AT WELL LOCATION Same  
 MAILING ADDRESS 7580 Tholl Road  
Reno, NV 89506  
 2. LOCATION SE 1/4 NW 1/4 Sec. 4 T. 20N N/S R. 19 E. Washoe County  
 PERMIT NO. 86-416-15 Parcel No. Lemmon Valley Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>WELL DEEPENING:</u>				
Brown rusty sand & silt		118	124	6
Black sandy silt		124	128	2
Granite		128	137	9
Brown decomposed granite		137	142	5
Light brown DG		142	146	4
Granite (med. hard)		146	150	4
Fracture		150	151	1
Granite		151	164	13
Fracture (est 1 gal)	X	164	165	1
Granite		165	171	6
Soft streak DG		171	180	9
Granite		180	188	8
<del>XXXXXX</del> Soft streak DG		188	191	3
Granite		191	193	2
Fracture (est 2 gal)		193	194	1
Granite		194	202	8
Fracture	X	202	206	4
Granite		206	218	12
Soft zone, DG weathered	X	218	250	32

8. WELL CONSTRUCTION  
 Depth Drilled 250 Feet Depth Cased 250 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 6 1/8 Inches 118 Feet To 250 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
5"		.188	0	250

Perforations:  
 Type perforation factory sawed slot  
 Size perforation 3/32 x 3 x 5 around  
 From 190 feet to 250 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Neat Cement  
 Cement Grout  
 Concrete Grout  
 Depth of Seal \_\_\_\_\_  
 Placement Method:  Pumped  Poured  
 Gravel Packed:  Yes  No  
 From 118 feet to 250 feet

9. WATER LEVEL  
 Static water level 90 feet below land surface  
 Artesian flow 30 G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature cold °F Quality clear

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Wayne Drilling, Inc. Contractor  
 Address P.O. Box 12370 Contractor  
Reno, NV 89510  
 Nevada contractor's license number issued by the State Contractor's Board 22549  
 Nevada driller's license number issued by the Division of Water Resources / the on-site driller 908  
 Signed [Signature]  
 By driller performing actual drilling on site or contractor  
 Date July 27, 1992

Date started 7-23-92, 19\_\_\_\_\_  
 Date completed 7-24-92, 19\_\_\_\_\_

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			