WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 38358
Permit No.
Basin 9.B

NOTICE OF INTENT NO. 21626

1. OWNER MARTIN GOMEZ/WESTERN TITLE
MAILING ADDRESS 225 So. Arlington
Reno, NV 89501

ADDRESS AT WELL LOCATION 11625 Tupelo
Reno, NV 89506

2. LOCATION SE ¼ NW ¼ Sec. 22 T 21N N/S R. 19 E. Washoe County
PERMIT NO. (Issued by Water Resources) 80-302-06 (Parcel No.) Lemmon Valley (Subdivision Name)

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☒ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Fill, fine green sand		65	70	5
Brown clay		70	82	12
Soft zone	X	82	84	2
Brown clay		84	90	6
Soft zone	X	90	92	2
Brown clay		92	107	15
Soft zone	X	107	116	9
Brown clay		116	126	10

'92 AUG 26 A11:41
STATE ENGINEER'S OFFICE

Date started 8-21-92, 19
Date completed 8-21-92, 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 61 Feet Depth Cased 126 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
6 1/8 Inches		70 Feet	126 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
5"		.188	0	126

Perforations:
Type perforation factory sawed slot
Size perforation 3/32 x 3 x 5 around
From 81 feet to 121 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☐ Yes ☒ No
Depth of Seal N/A
Placement Method: ☐ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 70 feet to 126 feet

9. WATER LEVEL
Static water level 52 feet below land surface
Artesian flow 15 G.P.M. P.S.I.
Water temperature cold °F Quality clear

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Wayne Drilling, Inc. (Contractor)
Address P.O. Box 12370 (Contractor)
Reno, NV 89510
Nevada contractor's license number issued by the State Contractor's Board 22549
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 923
Signed [signature] (By driller performing actual drilling on site or contractor)
Date August 22, 1992

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627