WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 38368
Permit No.
Basin 101

NOTICE OF INTENT NO. 20584

1. OWNER Richard Keene
MAILING ADDRESS 4437 Schurz Hwy.
Fallon, Nev. 89406

ADDRESS AT WELL LOCATION
4551 Resevoir Road
Fallon, Nev. 89406

2. LOCATION S/E ¼ S/W ¼ Sec. 27 T. 19 N/S R. 29 E. Churchill County
PERMIT NO. (Issued by Water Resources) 007-571-25 (Parcel No.) (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| Sand | | 0 | 2 | 2 |
| Brown Clay | | 2 | 5 | 3 |
| Brown Sand | X | 5 | 18 | 13 |
| Brown Clay | | 18 | 19 | 1 |

Date started August 3, 19 92
Date completed August 3, 19 92

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| | | |

8. WELL CONSTRUCTION
Depth Drilled 19 Feet Depth Cased 19 Feet

HOLE DIAMETER (BIT SIZE)

| | | From | To |
|---|---|---|---|
| 10 Inches | 0 Feet | 19 Feet | |
| Inches | Feet | Feet | |
| Inches | Feet | Feet | |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 6-5/8 | 12.92 | .188 | 0 | 19 |
| | | | | |
| | | | | |

Perforations:
Type perforation Mill Cut
Size perforation 1/8"
From 16 feet to 18 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 15'
Placement Method: ☒ Pumped ☐ Poured

Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 15 feet to 18 feet

9. WATER LEVEL
Static water level 6 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cool °F Quality Unknown

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name PARSONS DRILLING, INC. (Contractor)
Address P.O. BOX 1265 (Contractor)
FALLON, NEVADA 89407-1265
Nevada contractor's license number issued by the State Contractor's Board 29064
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1715
Signed Doug Parsons (By driller performing actual drilling on site or contractor)
Date Aug. 6, 1992

'92 AUG 12 A10:07
STATE ENGINEER'S OFFICE

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O) 627