WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 38424
Permit No.
Basin 162

NOTICE OF INTENT NO. 9561

1. OWNER Bill Stanton
MAILING ADDRESS
ADDRESS AT WELL LOCATION Street

2. LOCATION SE ¼ SW ¼ Sec. 9 T. 20S N/S R. 53 E. Nye County
PERMIT NO. N/A (Issued by Water Resources) 35-183-29 (Parcel No.) Cal Vegas Ranchos Lot 61 Unit D (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Clay		0'	4'	4'
Calichie		4'	8'	4'
Clay		8'	16'	8'
Calichie		16'	19'	3'
Clay		19'	28'	9'
Calichie		28'	32'	4'
Clay		32'	51'	19'
Calichie	WB	51'	63'	12'
Clay		63'	78'	15'
Calichie	WB	78'	86'	8'
Clay		86'	104'	18'
Calichie	WB	104'	109'	5'
Clay		109'	117'	8'
Calichie	WB	117'	123'	6'
Clay		123'	136'	13'
Calichie	WB	136'	140'	4'

RECEIVED
APR 23 1992
Div. of Water Resources
Branch Office - Las Vegas, NV

Date started 4-14, 19 92
Date completed 4-18, 19 92

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 140' Feet Depth Cased 140' Feet

HOLE DIAMETER (BIT SIZE)

Inches	From (Feet)	To (Feet)
12¼	0'	140'

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8	16.94	.188	0'	140'

Perforations:
Type perforation Sawcut
Size perforation 1/8 x 3
From 120 feet to 140 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50'
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 140' feet to 50' feet

9. WATER LEVEL
Static water level 99 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Great Basin Drilling (Contractor)
Address HCR 78 Box 80358 (Contractor)
Pahrump, Nv. 89041
Nevada contractor's license number issued by the State Contractor's Board 30880
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1642
Signed Thomas Dam (By driller performing actual drilling on site or contractor)
Date 4-20-92

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627