


Log No. 38475

Permit No. _____

Basin 1162



PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 9529

1. OWNER Norman Stock

ADDRESS AT WELL LOCATION Dickie Ave

MAILING ADDRESS _____

2. LOCATION SE 1/4 SE 1/4 Sec 11 T. 215 N/S R. 53 E Nye County

PERMIT NO. N/A Issued by Water Resources Parcel No. 44-313-13 Subdivision Name Joycely Est. Lot 2 BIK 9

3. WORK PERFORMED			4. PROPOSED USE			5. WELL TYPE		
<input checked="" type="checkbox"/> New Well	<input type="checkbox"/> Replace	<input type="checkbox"/> Recondition	<input checked="" type="checkbox"/> Domestic	<input type="checkbox"/> Irrigation	<input type="checkbox"/> Test	<input type="checkbox"/> Cable	<input checked="" type="checkbox"/> Rotary	<input type="checkbox"/> RVC
<input type="checkbox"/> Deepen	<input type="checkbox"/> Abandon	<input type="checkbox"/> Other _____	<input type="checkbox"/> Municipal/Industrial	<input type="checkbox"/> Monitor	<input type="checkbox"/> Stock	<input type="checkbox"/> Air	<input type="checkbox"/> Other _____	

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Clay		0'	8'	8'
Caliche		8'	15'	7'
Clay		15'	21'	6'
Caliche		21'	23'	2'
Clay		23'	59'	36'
Caliche		59'	61'	2'
Clay		61'	76'	15'
Caliche	WB	76'	82'	6'
Clay		82'	85'	3'
Caliche	WB	85'	92'	7'
Clay		92'	121'	29'
Caliche	WB	121'	129'	8'
Clay		129'	130'	1'
Caliche	WB	130'	140'	10'

8. WELL CONSTRUCTION

Depth Drilled 140' Feet Depth Cased 140' Feet

HOLE DIAMETER (BIT SIZE)

Inches	From	To
<u>12 1/4</u>	0'	140'
_____	_____	_____
_____	_____	_____

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>8 5/8</u>	<u>16.94</u>	<u>.188</u>	<u>0'</u>	<u>140'</u>
_____	_____	_____	_____	_____

Perforations:
 Type perforation sawcut
 Size perforation 1/8 x 3/8
 From 128 feet to 140 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50' Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 140' feet to 50' feet

RECEIVED

MAY 15 1992

Div. of Water Resources
 Branch Office - Las Vegas, NV

9. WATER LEVEL

Static water level 54 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

Date started 5-8 1992
 Date completed 5-12 1992

7. WELL TEST DATA

TEST METHOD: <input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)	

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Great Basin Drilling Contractor
 Address HCR 78 Box 80358 Contractor
Pahrump, NV. 89041
 Nevada contractor's license number issued by the State Contractor's Board 30880
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1642
 Signed Thomas Dun
 By driller performing actual drilling on site or contractor
 Date 5-13-92