WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 38489
Permit No.
Basin

NOTICE OF INTENT NO. 11053

1. OWNER Robert Sullivan
MAILING ADDRESS
ADDRESS AT WELL LOCATION Desert Hill Cr.

2. LOCATION NE ¼ NE ¼ Sec. 36 T. 21s N/S R. 53 E. Nye County
PERMIT NO. N/A (Issued by Water Resources) 29-191-20 (Parcel No.) Desert Hills Lot 20 Blk 1 (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sandy loam		0'	5'	5'
Calichie		5'	16'	11'
Clay		16'	21'	5'
Calichie		21'	36'	15'
Clay		36'	39'	3'
Calichie		39'	52'	13'
Clay		52'	69'	17'
Calichie		69'	74'	5'
Clay		74'	89'	15'
Calichie	WB	89'	94'	5'
Clay		94'	129'	35'
Calichie	WB	129'	142'	13'
Clay		142'	159'	17'
Calichie	WB	159'	164'	5'
Clay		164'	178'	14'
Calichie	WB	178'	180'	2'

RECEIVED
JUN 10 1992
Div. of Water Resources
Branch Office - Las Vegas, NV

Date started 5-13, 1992
Date completed 5-20, 1992

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 180' Feet Depth Cased 180' Feet

HOLE DIAMETER (BIT SIZE)

	From	To
12¼ Inches	0' Feet	180' Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8	16.94	.188	0'	180'

Perforations:
Type perforation Sawcut
Size perforation 1/8 x 3
From 160 feet to 180 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50'
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 180' feet to 50' feet

9. WATER LEVEL
Static water level 83 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cool °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Great Basin Drilling (Contractor)
Address HCR 78 Box 80358 (Contractor)
Pahrump, NV 89041
Nevada contractor's license number issued by the State Contractor's Board 30880
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1642
Signed Thomas Dann (By driller performing actual drilling on site or contractor)
Date 6-4-92

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627