

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
 Log No. 38498
 Permit No. _____
 Basin 162

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

NOTICE OF INTENT NO. 11075

1. OWNER Clarence Fulkerzon ADDRESS AT WELL LOCATION Quarter Horse
 MAILING ADDRESS _____

2. LOCATION NW 1/4 SW 1/4 Sec 20 T. 21 S N/S R. 54 E County Nye
 PERMIT NO. N/A Issued by Water Resources Parcel No. 45-311-15 Subdivision Name Green Saddle Ranch Lot 4

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Clay		0'	47'	47'
Caliche		47'	63'	16'
Clay		63'	67'	4'
Caliche	WB	67'	75'	8'
Clay		75'	79'	4'
Caliche	WB	79'	88'	11'
Clay		88'	98'	10'
Caliche	WB	98'	117'	19'
Clay		117'	124'	7'
Caliche	WB	124'	138'	14'
Clay		138'	140'	2'

8. WELL CONSTRUCTION
 Depth Drilled 140' Feet Depth Cased 140' Feet
 HOLE DIAMETER (BIT SIZE)
 From 0' To 140'
12 1/4 Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
85/8	16.94	.188	0'	140'

Perforations:
 Type perforation sawcut
 Size perforation 1/8 x 3
 From 125 feet to 140 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50' Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 140' feet to 50' feet

9. WATER LEVEL
 Static water level 5.4 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Great Basin Drilling Contractor
 Address HCR 78 Box 80358 Contractor
Pahrump, NV 89045
 Nevada contractor's license number issued by the State Contractor's Board 30880
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1642
 Signed Pharmas Durr
 By driller performing actual drilling on site or contractor
 Date 6-16-92

Date started 6-11 1992
 Date completed 6-16 1992

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			

RECEIVED
 JUN 22 1992
 Div. of Water Resources
 Branch Office - Las Vegas, NV