

OFFICE USE ONLY
 Log No. 98499
 Permit No. _____
 Basin 160

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 11077

1. OWNER Jerry Myers ADDRESS AT WELL LOCATION Savoy
 MAILING ADDRESS _____

2. LOCATION NW 1/4 SW 1/4 Sec 20 T 21s N/S R 54 E Nye County
 PERMIT NO. N/A 45-311-15 Green Saddle Ranch Lot 378
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Clay		0'	46'	46'
Caliche		46'	59'	13'
Clay		59'	66'	7'
Caliche		66'	75'	9'
Clay		75'	86'	11'
Caliche		86'	92'	6'
Clay		92'	98'	6'
Caliche		98'	113'	15'
Clay		113'	128'	9'
Caliche		122'	136'	14'
Clay		136'	140'	4'

8. WELL CONSTRUCTION
 Depth Drilled 140' Feet Depth Cased 140' Feet

HOLE DIAMETER (BIT SIZE)
 From 12 1/4 Inches To 0' Feet
140' Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>8 5/8</u>	<u>16.94</u>	<u>.188</u>	<u>0'</u>	<u>140'</u>

Perforations:
 Type perforation sawcut
 Size perforation 18 x 3
 From 120 feet to 140 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout

Depth of Seal 50'

Placement Method: Pumped
 Poured

Gravel Packed: Yes No
 From 140' feet to 50' feet

9. WATER LEVEL
 Static water level 54 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Great Basin Drilling
 Address HCR 78 Box 80358
Pahrump, NV 89041
 Nevada contractor's license number issued by the State Contractor's Board 30880
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1642
 Signed Thomas Deen
 By driller performing actual drilling on site or contractor
 Date 6-17-92

Date started 6-11 1992
 Date completed 6-16 1992

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

RECEIVED
 JUN 22 1992

Div. of Water Resources
 Branch Office - Las Vegas, NV