WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 38500
Permit No.
Basin 162

NOTICE OF INTENT NO. 9559

1. OWNER Carole Vilardo
MAILING ADDRESS
ADDRESS AT WELL LOCATION Pahrump

2. LOCATION SE ¼ SW ¼ Sec. 20 T. 21S N/S R. 54 E. Nye County
PERMIT NO. N/A (Issued by Water Resources) 45-314-03 (Parcel No.) Green Saddle Ranch Lot 2P (Subdivision Name)

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Clay		0'	23'	23'
Calichie		23'	34'	11'
Clay		34'	41'	7'
Calichie		41'	43'	2'
Clay		43'	52'	9'
Calichie		52'	54'	2'
Clay		54'	62'	8'
Calichie		62'	63'	1'
Clay		63'	81'	18'
Calichie	WB	81'	94'	13'
Clay		94'	107'	13'
Calichie	WB	107'	113'	6'
Clay		113'	119'	6'
Calichie	WB	119'	123'	4'
Clay		123'	130'	7'
Calichie	WB	130'	140'	10'

Date started 4-14, 19 92
Date completed 4-16, 19 92

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

RECEIVED
APR 21 1992
Div. of Water Resources
Branch Office - Las Vegas, NV

8. WELL CONSTRUCTION
Depth Drilled 140' Feet Depth Cased 140' Feet

HOLE DIAMETER (BIT SIZE)

Inches	From (Feet)	To (Feet)
12 1/4	0'	140'

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8	16.94	.188	0'	140'

Perforations:
Type perforation Sawcut
Size perforation 1/8 x 3
From 120 feet to 140 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50'
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [ ] Cement Grout [X] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 140' feet to 50' feet

9. WATER LEVEL
Static water level 55 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Great Basin Drilling (Contractor)
Address HCR 78 Box 80358 (Contractor)
Pahrump, Nv. 89041
Nevada contractor's license number issued by the State Contractor's Board 30880
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1642
Signed Thomas Dam
By driller performing actual drilling on site or contractor
Date 4-16-92

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627