WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 38546
Permit No.
Basin 105

NOTICE OF INTENT NO. 19748

1. OWNER Michael Const
MAILING ADDRESS 777 Saddle Ct. Gardnerville NV.
ADDRESS AT WELL LOCATION 777 Saddle Ct. Gardnerville NV.

2. LOCATION NW ¼ NE ¼ Sec. 24 T. 12 N/S R. 21 E. Douglas County
PERMIT NO. (Issued by Water Resources) 29-462-09 (Parcel No.) Ruenstrath Flats (Subdivision Name)

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☑ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☑ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Brown Clay		0'	15'	15'
Gravel		15'	35'	20'
Gumbo Brown Clay		35'	60'	25'
Broken Hard Volcanic Rock		60'	130'	70'
Gravels w/ Small amount of Water	X	130	135	5'
Broken Volcanic Rock		135'	160'	25'
Gravel w/ Small Clay Seams		160'	185'	
Gravels, Water Zone	XX	185'	200'	
T.D 200'				
Static 100'				
G.P.M 25				

Date started 8-11, 1992
Date completed 8-12, 1992

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☑ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
25	20	2½

8. WELL CONSTRUCTION
Depth Drilled 200' Feet Depth Cased 200' Feet

HOLE DIAMETER (BIT SIZE)

	From	To
11¾ Inches	0' Feet	55' Feet
9⅞ Inches	55 Feet	200' Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6⅝	12.92	.188	0	200'

Perforations:
Type perforation Millshot
Size perforation 3½ X 3/32
From feet to feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 55
Placement Method: ☐ Pumped ☑ Poured
Seal Type: ☐ Neat Cement ☑ Cement Grout ☐ Concrete Grout
Gravel Packed: ☑ Yes ☐ No
From 0 feet to 55' feet

9. WATER LEVEL
Static water level 100' feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name H.H. Pump Co. (Contractor)
Address 5551 Hy 50 E. #3 (Contractor)
Carson City NV. 89701
Nevada contractor's license number issued by the State Contractor's Board 31839
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1674
Signed Joe Butts
By driller performing actual drilling on site or contractor
Date

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627