WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 38556
Permit No.
Basin

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 11365

1. OWNER Round Mountain Gold Corp.
MAILING ADDRESS P.O. Box 480 Round Mountain, Nv.
ADDRESS AT WELL LOCATION open Pit Minesite

2. LOCATION NW ¼ SW ¼ Sec. 19 T. 10 N/S R. 44 E. Nye County
PERMIT NO. M/O 574 (Issued by Water Resources) | Parcel No. | Subdivision Name

3. TYPE OF WORK: New Well ☑ Recondition ☐ Deepen ☐ Other ☐

4. PROPOSED USE: Domestic ☐ Irrigation ☐ Test ☐ Monitor ☑ Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL: Cable ☐ Rotary ☒ Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Back fill		0	23	
Alluvium		23	80	
Bouldery		80	86	
sd + gravel		86	182	
Clay w/gravel, Trace Basalt		182	310	
Red ish/yellow clay		310	317	
Boulders		317	321	
Brown clay		321	328	
Tuffs		328	405	
Boulders		405	411	
Sticky Red/light. clay		411	445	
sd + gravel	✓	445	465	

Received orders To Plug + Abandon This well.
Procedures:
Run To bottom of hole w/D.P., circ 55 Vis. Mud, 9.5 PPG., pull up To 60', mix 30 sks Cement, Pump To Surface. POH, Fill To TOP.

Date started 7-8, 1992
Date completed 7-16, 1992

7. WELL TEST DATA N/A

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST N/A
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter 14 3/4 inches Total depth 465 feet
8 3/4 inches
inches
Casing record 10"
Weight per foot 28.05 Thickness .250

Diameter	From	To
10 inches	+1 feet	50 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type NEAT cement
Depth of seal 50 feet
Gravel packed: Yes ☐ No ☒
Gravel packed from ..... feet to ..... feet

Perforations: No production string set
Type perforation
Size perforation
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 447 feet below land surface
Flow No Test G.P.M. No Test P.S.I.
Water temperature C °F Quality No Test

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Woytek Drilling Co. (Contractor)
Address 2220 Stowe Dr Reno, Nv. (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 024521
Nevada contractor's driller's number issued by the Division of Water Resources 1374
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1442
Signed Leo Woytek (By driller performing actual drilling on site or contractor)
Date 7-28-92

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627