

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 18378

1. OWNER Jugles Coust ADDRESS AT WELL LOCATION 5015 Saddlewood
MAILING ADDRESS 2150 Mutie View Drive
Fallon 89406

2. LOCATION SE 1/4 SE 1/4 Sec 29 T. 19 N/S R 28 E Churchill County
PERMIT NO. 08651-07 Parcel No. _____ Subdivision Name Copperwood

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
F. Soil		0	2	2
Fine Sand	✓	2	14	12
clay		14	21	7
Dark Sand	✓	21	29	8
Dark Clay		29	35	6
Dark Silty Sand	✓	35	65	30
Grey Clay		65	72	7
Fine yellow sand	✓	72	76	4
Grey clay		76	83	7
Grey silty sand	✓	83	115	32
Brown Sand		115	121	6
Brown Fine Sand	✓	121	149	28

8. WELL CONSTRUCTION
Depth Drilled 149 Feet Depth Cased 149 Feet

HOLE DIAMETER (BIT SIZE)
From To
10 Inches 6 Feet 100 Feet
6 Inches 50 Feet 149 Feet
Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6.75</u>		<u>0.185</u>	<u>0</u>	<u>149</u>

Perforations:
Type perforation Machinist slot
Size perforation 0.050
From 142 feet to 146 feet
From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
Depth of Seal 100 Neat Cement
Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
From _____ feet to _____ feet

9. WATER LEVEL
Static water level 14 feet below land surface
Artesian flow _____ G.P.M. _____ P.S.I.
Water temperature 56 °F Quality _____

Date started Feb-7 1992
Date completed Feb-9 1992

7. WELL TEST DATA

TEST METHOD: Bailor Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>50</u>		<u>1</u>

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name J.W. Biffle Contractor
Address Box 888 Contractor
Fallon
Nevada contractor's license number issued by the State Contractor's Board 11952
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 772
Signed J.W. Biffle
By driller performing actual drilling on site or contractor
Date Feb 12-92