


OFFICE USE ONLY
 Log No. 38568
 Permit No. _____
 Basin. 1.01



PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 17096

1. OWNER Copas Const ADDRESS AT WELL LOCATION 1000 Riverside
 MAILING ADDRESS 170 Frels-Way

2. LOCATION SW 1/4 NW 1/4 Sec 34 T. 19 N/S R. 28 E Churchill County
 PERMIT NO. 8-411-24 Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Sand		0	12	12
Silty Sand		12	27	15
Grey Clay		27	31	4
Grey Gravel		31	39	8
Black Clay		39	46	7
Black silt		46	64	18
Grey Gravel		64	83	19
Brown Clay		83	86	3
Fine yellow sand		86	96	10
Silt		96	116	20
Brown Clay		116	121	5
Brown silt		121	160	39
Sand & Gravel		160	172	12

8. WELL CONSTRUCTION
 Depth Drilled 172 Feet Depth Cased 172 Feet

HOLE DIAMETER (BIT SIZE)
 From 10 Inches 0 Feet 100 Feet
 To 6 Inches 100 Feet 172 Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>12.9</u>	<u>0.188</u>	<u>±1</u>	<u>172</u>

Perforations:
 Type perforation Machine slot
 Size perforation 3/32
 From 165 feet to 170 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout

Depth of Seal 100
 Placement Method: Pumped Poured

Gravel Packed: Yes No
 From _____ feet to _____ feet

92 APR 14 AM 22
 RECEIVED
 STATE ENGINEERS OFFICE

9. WATER LEVEL
 Static water level _____ feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Webco Contractor
 Address Box 888 Contractor
Fallon NV.
 Nevada contractor's license number issued by the State Contractor's Board 11752
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 772
 Signed [Signature]
 By driller performing actual drilling on site or contractor
 Date _____

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>50</u>	<u>1</u>	

Date started 2-28, 1992
 Date completed 2-29, 1992