WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 3851
Permit No.
Basin 103

NOTICE OF INTENT NO. 17712

1. OWNER ISAIAH COUST / STEVE WOOD
MAILING ADDRESS 2330 DAMON RD
CARSON CITY, NV 89701

ADDRESS AT WELL LOCATION 304 SYDNEY LANE
DAYTON, NV 89403

2. LOCATION SW ¼ NW ¼ Sec. 16 T. 16 N/S R. 22 E. LYON County
PERMIT NO. (Issued by Water Resources) 19-541-08 (Parcel No.) BANCHO VISTA (Subdivision Name)

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☑ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☑ Rotary ☐ RVC
☐ Air ☐ Other MUD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
SANDY OVERBURDEN		0	5	5
SAND, FINE to COARSE		5	22	17
DG. SAND		22	87	65
CLAY SEAM		87	95	8
VOLCANIC SAND		95	125	30
CLAY W/SAND		125	135	10
VOLCANIC SANDS W/ CLAY SEAMS		135	190	55
CLAY & CEMENTED SAND		190	205	15
VOLCANIC ROCK W/ CLAY STRINGERS		205	265	60
FRACTURED GRANITE W/ WATER	✓	267	275	10
T.D. 275 FT				

Date started Feb 4, 19 92
Date completed Feb 7, 1992

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☑ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
Blew well for 4 hours to remove drill mud & clean & develop		
Blowing 30 GPM from 240 feet		

8. WELL CONSTRUCTION
Depth Drilled 275 Feet Depth Cased 275 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 3/4 Inches		0 Feet	70 Feet
9 1/2 Inches		70 Feet	275 Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13.03	.188	+2	275

Perforations:
Type perforation FACTORY SLOTTED
Size perforation 3/32" X 3"
From 250 feet to 270 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 60
Placement Method: ☐ Pumped ☑ Poured
Seal Type: ☐ Neat Cement ☑ Cement Grout ☐ Concrete Grout
Gravel Packed: ☑ Yes ☐ No
From 60 feet to 275 feet

9. WATER LEVEL
Static water level 80 feet below land surface
Artesian flow 30 G.P.M. P.S.I.
Water temperature COLD °F Quality GOOD

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name A+H PUMP CO (Contractor)
Address 5351 HIWAY 50 E (Contractor)
CARSON CITY, NV 89701
Nevada contractor's license number issued by the State Contractor's Board 31839
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1544
Signed Marvin L Hocks (By driller performing actual drilling on site or contractor)
Date Feb 7, 1992

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627