WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 38575
Permit No.
Basin 105

NOTICE OF INTENT NO. 19400

1. OWNER Steven Cook
MAILING ADDRESS PO Box 157
Minden, NV 89423

ADDRESS AT WELL LOCATION parcel 35-310-35
Cavelti Rd

2. LOCATION SW ¼ SE ¼ Sec. 35 T. 11 N/S R. 21 E. Douglas County
PERMIT NO. (Issued by Water Resources) 35-310-35 (Parcel No.) Spring Valley (Subdivision Name)

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Boulders		0		20
Shale & Clay		20		40
Soft Shale		40		60
Shale & gravel		60		80
Brn clay - Shale		80		100
Volcanic Rock		100		120
Volcanic Rock		120		140
Shale, Clay		140		160
Hard pack Shale		160		180
Shale - Volcanic		180		200
Soft Shale - Void		200		220
Void - Volcanic		220		240
Hard Shale		240		260
Brn clay - Shale		260		280
Broken Shale		280		300
Broken Shale		300		320
Shale		320		340
Shale		340		360
Hard Volcanic		360		380
Volcanic - Shale		380		400
Soft Shale		400		410

Date started 12/30/91, 1991
Date completed 1/27/92, 1992

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 410 Feet Depth Cased 410 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 Inches		0 Feet	200 Feet
6 Inches		200 Feet	400 Feet
6 Inches		400 Feet	420 Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6"		.188	0	200
5"		.188	180	400
5"		.188	400	420

Perforations:
Type perforation 3/32 x 3" Factory
Size perforation 3/32 x 3
From 360 feet to 410 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50'
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [ ] Cement Grout [X] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 200 feet

9. WATER LEVEL
Static water level 310 feet below land surface
Artesian flow G.P.M. 10 P.S.I.
Water temperature cool °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Ed Miller (Contractor)
Address 200 Artist Veiw (Contractor)
Wellington NV. 89444
Nevada contractor's license number issued by the State Contractor's Board 32166
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 718T
Signed Jeff Steele (By driller performing actual drilling on site or contractor)
Date 1/27/92

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627