

OFFICE USE ONLY  
 Log No. 38581  
 Permit No. \_\_\_\_\_  
 Basin. 105

T

NOTICE OF INTENT NO. 19430

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER MR. REESE BORDELEN ADDRESS AT WELL LOCATION 1539 SCOTI LANE  
 MAILING ADDRESS 1539 SCOTI LANE GARDNERVILLE, NV  
 2. LOCATION SW 1/4 SE 1/4 Sec. 37 T. 13 N. R. 20 E DOUGLAS County  
 PERMIT NO. 23-462-CY SIERRA SUNSET HEIGHTS #2 Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other MUD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
SANDY CLAY		0	8	8
SAND		8	26	18
SANDY CLAY		26	38	12
SAND + GRAVEL		38	49	11
LARGE GRAVEL + SAND		49	72	23
CLAY		72	75	3
SANDY CLAY		75	136	61
COARSE SAND	✓	136	160	24

92 JAN 31 AM 100 STATE ENGINEER

8. WELL CONSTRUCTION  
 Depth Drilled 160 Feet Depth Cased 160 Feet

HOLE DIAMETER (BIT SIZE)  
 From 10 5/8 Inches To 0 Fcct 160 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Fcct

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>17</u>	<u>.188</u>	<u>0</u>	<u>160</u>

Perforations:  
 Type perforation FACTORY SINGLE  
 Size perforation 3 x 3/32  
 From 140 feet to 160 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 50  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout

Gravel Packed:  Yes  No  
 From 50 feet to 160 feet

9. WATER LEVEL  
 Static water level 27 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature COLD °F Quality GOOD

Date started 1-22, 1992  
 Date completed 1-29, 1992

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>AIR</u>	<u>25+</u>	<u>—</u>	<u>1</u>

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name EDDICO EXPLORATION INC. Contractor  
 Address 7780 CURRY RD. Contractor  
FALLOON, NV 89406  
 Nevada contractor's license number 27673  
 issued by the State Contractor's Board.  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1726  
 Signed Paul J. Moore  
 By driller performing actual drilling on site or contractor  
 Date 1-29-92