WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 38582
Permit No.
Basin 105

NOTICE OF INTENT NO. 16910

1. OWNER Bob Parkett
MAILING ADDRESS 460 Pecan St. Arroyo Grande Calif. 93420
ADDRESS AT WELL LOCATION 1764 Bitterbrush Gard. Nv.

2. LOCATION NE ¼ SW ¼ Sec. 36 T. 13 N/S R. 20 E. Douglas County
PERMIT NO. Issued by Water Resources | Parcel No. 23-473-07 | Subdivision Name Wildflower

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| Clay | | 0 | 10 | |
| Gravel & Clay | | 10 | 30 | |
| Gravel | | 30 | 55 | |
| Gravel Rocks & Sand | | 55 | 80 | |
| Gravel & Sand | | 80 | 105 | |
| Sand | | 105 | 165 | |
| Sand & Clay | | 165 | 190 | |
| Sand | | 190 | 210 | |
| Sand & Clay | | 210 | 230 | |

'92 MAR -5 A10:56
RECEIVED
STATE ENGINEERS OFFICE

Date started 1-2, 1992
Date completed 1-4, 1992

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

| | G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|---|
| Air | 50 EOT | | 2 hrs |

8. WELL CONSTRUCTION
Depth Drilled 230 Feet Depth Cased 230 Feet

HOLE DIAMETER (BIT SIZE)

| | From | To |
|---|---|---|
| 10 Inches | 0 Feet | 230 Feet |
| Inches | Feet | Feet |
| Inches | Feet | Feet |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 6 5/8 | 8 lbs | .219 | 0 | 230 |

Perforations:
Type perforation Factory Cut
Size perforation 3" X 5/32"
From 230 feet to 210 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50 FT.
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 230 feet to 50 feet

9. WATER LEVEL
Static water level 76 feet below land surface
Artesian flow – G.P.M. – P.S.I.
Water temperature Cold °F Quality –

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Kaufhoek Drilling Inc. Contractor
Address 2068 Fuller Minden NV 89423 Contractor

Nevada contractor's license number issued by the State Contractor's Board #021268
Nevada driller's license number issued by the Division of Water Resources, the on-site driller #1495
Signed Michael Allen
By driller performing actual drilling on site or contractor
Date 1-22-92

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627