



PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 15143

1. OWNER: Dave Merrill ADDRESS AT WELL LOCATION: 3638 Summerhill  
 MAILING ADDRESS: 3638 Summerhill  
Crescent City NV 89001

2. LOCATION: SW 1/4 SE 1/4 Sec 6 T 14 N/S R 20 E Douglas County  
 PERMIT NO. 13-102-01 Parcel No. Jacks Valley Subdivision Name

3. WORK PERFORMED:  New Well  Replace  Recondition  Deepen  Abandon  Other

4. PROPOSED USE:  Domestic  Municipal/Industrial  Irrigation  Monitor  Test  Stock

5. WELL TYPE:  Cable  Rotary  RVC  Air  Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
CLAY		0	15	
CLAY AND ROCK		15	25	
DEEP SAND		25	65	
ROCK		65	70	
CLAY & SAND		70	130	
SANDSTONE CLIFFS		130	230	

8. WELL CONSTRUCTION  
 Depth Drilled: 230 Feet Depth Cased: 230 Feet

HOLE DIAMETER (BIT SIZE)  
 From 3.10 Inches To 0 Feet 230 Feet  
 Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>8 1/2</u>	<u>.217</u>	<u>0</u>	<u>230</u>

Perforations:  
 Type perforation: Factory cut  
 Size perforation: 3" x 3/32"  
 From 230 feet to 20 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  Neat Cement  Cement Grout  Concrete Grout  
 Depth of Seal: 50 ft.  
 Placement Method:  Pumped  Poured

Gravel Packed:  Yes  No  
 From 230 feet to 50 feet

9. WATER LEVEL  
 Static water level: 118 feet below land surface  
 Artesian flow: \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature: cool °F Quality: \_\_\_\_\_

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name: Kauchuk Drilling Inc. Contractor  
 Address: 2668 Fuller, Minden, NV. Contractor 81403  
 Nevada contractor's license number issued by the State Contractor's Board: #021268  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller: #1495  
 Signed: Michael Allen  
 By driller performing actual drilling on site or contractor  
 Date: 1-22-92

Date started: 1-11, 1992  
 Date completed: 1-15, 1992

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>1410</u>	<u>20-25 gpm</u>		<u>2 1/2 hrs</u>