WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 38585
Permit No.
Basin 105

NOTICE OF INTENT NO. 19415

1. OWNER NEVADA JOHNSON
MAILING ADDRESS GARDNERVILLE, NV

ADDRESS AT WELL LOCATION 2813 SERVIRES RD. GARDNERVILLE, NV

2. LOCATION SE ¼ SW ¼ Sec. 27 T 14 N R 20 E DOUGLAS County
PERMIT NO. — (Issued by Water Resources) | 21-140-30 04 A2 (Parcel No.) | JOHNSON LANE (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☒ Other MUD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
SANDY CLAY		0	58	58
CLAY		58	63	5
SANDY CLAY		63	99	36
CLAY		99	106	7
SANDY CLAY		106	120	14
CLAY		120	123	3
SANDY CLAY		123	145	22
CLAY		145	149	4
FINE SAND		149	156	7
CLAY		156	159	3
SANDY CLAY	✓	159	190	31
CLAY		190	193	3
COARSE SAND	✓	193	208	15
CLAY		208	210	2
SAND	✓	210	214	4
CLAY		214	215	1

Date started 1-17, 1992
Date completed 1-23, 1992

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
AIR	15	—	2

8. WELL CONSTRUCTION
Depth Drilled 215 Feet Depth Cased 215 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 3/8 Inches		0 Feet	195 Feet
5 7/8 Inches		195 Feet	215 Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 3/8	17	.188	0	195
5	11	.188	195	215

Perforations:
Type perforation FACTORY SINGLE
Size perforation 3 x 3/32
From 175 feet to 195 feet
From 195 feet to 215 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 195 feet

9. WATER LEVEL
Static water level 115 feet below land surface
Artesian flow — G.P.M. — P.S.I.
Water temperature COLD °F Quality GOOD

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name EDDIE EXPLORATION, INC. (Contractor)
Address 7780 CURRY RD. (Contractor)
FALLON, NV 89406
Nevada contractor's license number issued by the State Contractor's Board 27673
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1726
Signed Patl J. Moore (By driller performing actual drilling on site or contractor)
Date 1-23-92

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627