

STATE OF NEVADA  
 DIVISION OF WATER RESOURCES  
**WELL DRILLER'S REPORT**

OFFICE USE ONLY  
 Log No. 38586  
 Permit No. \_\_\_\_\_  
 Basin 105  
 NOTICE OF INTENT NO. 19416

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER NEVADA JOHNSON ADDRESS AT WELL LOCATION \_\_\_\_\_  
 MAILING ADDRESS GARDNERVILLE, NV 2819 SQUIRES RD.  
GARDNERVILLE, NV  
 2. LOCATION SE 1/4 SW 1/4 Sec 27 T 14 N R 20 E DOUGLAS County  
 PERMIT NO. 21-140-30 D4 A1 JOHNSON LANE Subdivision Name  
 Issued by Water Resources Parcel No. \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other MUD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
SANDY CLAY w/ GRAVEL		0	12	12
SANDY CLAY		12	58	46
CLAY		58	63	5
SANDY CLAY		63	99	36
CLAY		99	106	7
SANDY CLAY		106	120	14
CLAY		120	123	3
SANDY CLAY		123	132	9
CLAY		132	135	3
SANDY CLAY		135	145	10
FINE SAND		145	158	13
COARSE SAND	✓	158	194	36
CLAY		194	195	1+

8. WELL CONSTRUCTION  
 Depth Drilled 195 Feet Depth Cased 195 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From To  
10 5/8 Inches 0 Feet 195 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>17</u>	<u>.188</u>	<u>0</u>	<u>195</u>

Perforations:  
 Type perforation FACTORY SINGLE  
 Size perforation 3 X 3/32  
 From 175 feet to 195 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 50  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 50 feet to 195 feet

9. WATER LEVEL  
 Static water level 115 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature COLD °F Quality GOOD

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name EDDCO EXPLORATION, INC Contractor  
 Address 7780 CURRY RD. Contractor  
FALLON, NV  
 Nevada contractor's license number 27673  
 issued by the State Contractor's Board  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1726  
 Signed Pat J. Mooney  
 By driller performing actual drilling on site or contractor  
 Date 1-16-92

Date started 1-13, 1992  
 Date completed 1-16, 1992

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailor <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift			
<u>AIR</u>	<u>15</u>	<u>—</u>	<u>2</u>

'92 JAN 31 AM 1:00  
 STATE ENGINEERING CO.