

**WELL DRILLER'S REPORT**

PRINT OR TYPE ONLY

Please complete this form in its entirety

NOTICE OF INTENT NO. 19179

1. OWNER Le N Ranch ADDRESS AT WELL LOCATION Grant View  
 MAILING ADDRESS P.O. Box 49 CRIVE Smith NV 89430  
Smith NV 89430  
 2. LOCATION SW 1/4 SW 1/4 Sec. 33 T. 11 N/S R. 33 E. 40N County \_\_\_\_\_  
 PERMIT NO. 09-061-10 Issued by Water Resources Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_

3. TYPE OF WORK  
 New Well  Recondition   
 Deepen  Other   
 4. PROPOSED USE  
 Domestic  Irrigation  Test   
 Municipal  Industrial  Stock  Other   
 5. TYPE WELL  
 Cable  Rotary   
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top Soil - Sand		0	20	
CLAY - GRAVEL		20	40	
GRAVEL - Sand		40	60	
Bkn Clay		60	80	
BRN CLAY		80	100	
CLAY - GRAVEL		100	120	
CLAY GRAVEL		120	140	
HARD PAN		140	160	
CLAY - GRAVEL		160	180	
CLAY - GRAVEL		180	200	
CLAY - GRAVEL		200	220	
GRAVEL - Sand		220	240	
GRAVEL	✓	240	260	
GRAVEL	✓	260	280	
GRAVEL	✓	280	300	

'92 APR 13 P2:56  
 STATE ENGINEERS OFFICE

8. WELL CONSTRUCTION  
 Diameter 10 inches Total depth 300 feet  
 Casing record Steel CASING  
 Weight per foot \_\_\_\_\_ Thickness 188  

Diameter	From	To
<u>6"</u> inches	<u>0</u> feet	<u>300</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

 Surface seal: Yes  No  Type portland mix  
 Depth of seal 50' feet  
 Gravel packed: Yes  No   
 Gravel packed from 50 feet to 300 feet  
 Perforations:  
 Type perforation FACTORY SLOT  
 Size perforation 3/32 x 3"  
 From 240 feet to 300 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Date started 2/18/92, 19\_\_\_\_\_  
 Date completed 2/21/92, 19\_\_\_\_\_

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
<u>90PSE</u>	<u>20+</u>	<u>60'</u>	<u>4</u>
<u>1500 RPM</u>			

BAILER TEST

G.P.M.	Draw down	feet	hours

9. WATER LEVEL  
 Static water level 147' feet below land surface  
 Flow 20+ G.P.M. 90 P.S.I.  
 Water temperature 60 °F Quality Good

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name EMALCO CORP Contractor  
 Address 200 ARTIST VIEW Wellington Contractor 89444  
 Nevada contractor's license number issued by the State Contractor's Board 32166  
 Nevada contractor's driller's number issued by the Division of Water Resources 718  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 718T  
 Signed Jeffery Steele By driller performing actual drilling on site or contractor  
 Date 2/21/92