

OFFICE USE ONLY  
 Log No. 38593  
 Permit No. \_\_\_\_\_  
 Basin 108

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in  
 accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 16619

1. OWNER Edward D Johnson ADDRESS AT WELL LOCATION #5 Rock Road  
 MAILING ADDRESS 4650 Sierra Madre #828 Yerington Nev 89447  
Reno Nev. 89502  
 2. LOCATION NE 1/4 NE 1/4 Sec 9 T. 13 N/R 26 E Lyon County  
 PERMIT NO. 14-611-18 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Hard Pan - Clay		0	1	1
Fine Sand + Clay		1	5	4
Clay + Coarse Sand		5	12	7
Coarse Sand + Gravel Fill		12	36	24
Coarse Sand - Gravel - Rock		36	70	34
Fine to Coarse Sand + Gravel		70	94	24
Clay + Coarse Sand		94	97	3
Coarse Sand - Gravel - Rock	X	97	136	39
Coarse Sand - Gravel - Clay		136	140	4
Coarse Sand - Gravel - Rock	X	140	150	10

'92 MAY -5 AND OF STATE ENGINEERS OF

8. WELL CONSTRUCTION  
 Depth Drilled 150 Feet Depth Cased 157 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 10 5/8 Inches To 0 Feet 150 Feet  
 Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 CASING SCHEDULE  

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>12.92</u>	<u>1.88</u>	<u>71</u>	<u>150</u>

Perforations:  
 Type perforation Sawed  
 Size perforation 4 1/2 x 3" 6 ROWS  
 From 130 feet to 150 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 50  Neat Cement  
 Placement Method:  Pumped  Concrete Grout  
 Poured  
 Gravel Packed:  Yes  No  
 From 50 feet to 150 feet

9. WATER LEVEL  
 Static water level 36 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature 60d °F Quality Good

Date started Jan 13, 1992  
 Date completed Jan 17, 1992

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input checked="" type="checkbox"/> Bailer <input checked="" type="checkbox"/> Pump <input type="checkbox"/> Air Lift			
<u>Bailer</u>	<u>30</u>	<u>2'</u>	<u>1/2 Hours</u>
<u>Pump</u>	<u>30</u>	<u>2'</u>	<u>1 Hours</u>

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Ogden Bros Drilling Contractor  
 Address 162 N By Bee Lane Contractor  
Yerington Nev 89447  
 Nevada contractor's license number issued by the State Contractor's Board 15646  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 634  
 Signed Larry Ogden  
 By driller performing actual drilling on site or contractor  
 Date Jan 26 1992