

OFFICE USE ONLY
 Log No. 38595
 Permit No. _____
 Basin 108

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 20191

1. OWNER Larry Masini ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS HWY 95-A 225 _____
Yerington, Nv. 89447 _____
 2. LOCATION SW 1/4 SW 1/4 Sec. 8 T 14 N/S R. 25 E Lyon County _____
 PERMIT NO. 30191 Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition Domestic Irrigation Test Cable Rotary RVC
 Deepen Abandon Other _____ Municipal/Industrial Monitor Stock Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Clay & Top Soil		0	15	15
Sand & Gravel		15	18	3
Brown Clay		18	52	34
Brown Clay/ Sand Stringers		52	57	5
Course Sand/ Gravel	x	57	70	13
Brown Clay		70	73	3
Sand and Gravel	x	73	79	6
Brown Clay		79	82	3
Sand & Gravel	x	82	93	11
Brown Clay		93	98	5
Sand and Gravel	x	98	102	4
Brown Clay		102	104	2
Sand & Gravel	x	104	110	6
Clay w/s Sand Stringers		110	125	15
Sand, Gravel/Clay Str.	x	125	170	45
Clay/ Sand Stringers		170	195	25
Sand, Gravel /Clay Str.	x	195	310	115
Blue Clay/ Sand Stringers		310	440	130
Dark Grey Sand, Clay		440	457	17
Decomposed Granite	x	457	458	1
Dark Grey Clay		458	520	62

8. WELL CONSTRUCTION
 Depth Drilled 520 Feet Depth Cased 500 Feet
 HOLE DIAMETER (BIT SIZE)
 From To
34 Inches 0 Feet 50 Feet
24 Inches 0 Feet 520 Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)	
16"	42.05	.250	blank	+2	75
30"	n/a	culvert	+1	50	

Perforations:
 Type perforation Louvered & Mill
 Size perforation 1/8 X 3 - 1/8 X 2
 From 75 feet to 100 standard feet
 From 100 feet to 200 dbl perf feet
 From 200 feet to 300 louvered feet full fl
 From 300 feet to 400 single mill feet
 From 400 feet to 500 dbl mill feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50' Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 0 feet to 520 feet

9. WATER LEVEL
 Static water level 28' feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature cold °F Quality good

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Humboldt Drilling and Pump Co. Contractor
 Address P.O. Box 590 Contractor
Winnemucca, Nevada 89446-0590
 Nevada contractor's license number 015234
 issued by the State Contractor's Board
 Nevada driller's license number issued by the 795
 Division of Water Resources, the on-site driller.
 Signed [Signature]
 By drilling performing actual drilling on site or contractor
 Date 2/7/92

Date started 2-1 1992
 Date completed 2-3 1992

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input checked="" type="checkbox"/> Pump <input type="checkbox"/> Air Lift	<u>4000+</u>	<u>132'</u>	<u>8 hrs.</u>

GPS shows well SESE see T by less than 10' to close to can.