WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

PRINT OR TYPE ONLY

OFFICE USE ONLY
Log No. 3863D
Permit No. 56895
Basin 049-Elko Segment

NOTICE OF INTENT NO. 1[illegible]34

1. OWNER Bannock Paving
MAILING ADDRESS P.O. Box 3429
Ogden UT, 84409

ADDRESS AT WELL LOCATION OSINO Gravel Pit

2. LOCATION SE ¼ SE ¼ Sec. 9 T. 35 N/S R. 56 E ELKO County
PERMIT NO. W-358 (Issued by Water Resources) | Parcel No. | Subdivision Name

3. TYPE OF WORK: New Well ☒ Recondition ☐ Deepen ☐ Other ☐

4. PROPOSED USE: Domestic ☐ Irrigation ☐ Test ☐ Municipal ☐ Industrial ☒ Stock ☐

5. TYPE WELL: Cable ☐ Rotary ☒ Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand gravel		0	58	58
Brown clay sand		58	106	50
Sand gravel		106	140	34
Brown clay sand	X	140	160	20
gravel sand		160	178	18
clay		178	194	16
gravel sand		194	200	6
Clay	X	200	246	46
gravel clay sand		246	262	16
gravel sand	X	262	270	8
Clay sand	X	270	284	14
gravel sand w		284	302	18
gravel clay w		302	320	18
gravel sand	X	320	360	40
gravel sand clay		360	402	42
gravel sand	X	402	422	20
Clay sand		422	431	9
Clay		431	440	9

Date started Feb - 1, 1992
Date completed Feb 11, 1992

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
1200	380	360	8

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter hole 12 inches Total depth 440 feet
Casing record
Weight per foot ..... Thickness 250

Diameter	From	To
12 inches	0 feet	440 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type Neat cement
Depth of seal 100 Ft feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 100 feet to 440 feet

Perforations:
Type perforation Factory
Size perforation 1/8 x 3 1/2
From 120 feet to 160 feet
From 200 feet to 220 feet
From 260 feet to 340 feet
From 400 feet to 420 feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 40 feet below land surface
Flow ..... G.P.M. ..... P.S.I.
Water temperature ..... °F. Quality

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name AAA Drilling (Contractor)
Address 181-14 West Bullion Elko NV (Contractor)
Nevada contractor's license number 0020684
Nevada contractor's drillers number
Nevada driller's license number 1438 SHANE BENNETT (Actual Driller)
Signed AAA Drilling (Contractor)
Date Mar 10 - 92

USE ADDITIONAL SHEETS IF NECESSARY

(Rev. 6-81) O-627 CR434