WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 38639
Permit No.
Basin 70

NOTICE OF INTENT NO. 73851

1. OWNER Gerald & Diannia Moritz
MAILING ADDRESS 9116 Bighorn #9802
Winnemucca NV. 89445

ADDRESS AT WELL LOCATION 9116 Bighorn
Winnemucca, NV

2. LOCATION NW ¼ NW ¼ Sec. 25 T. 35 N/S R. 36 E. Humboldt County
PERMIT NO. "NA" Issued by Water Resources | 05-512-19 Parcel No. | Grass Valley Ranches Subdivision No. 2 Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top Soil		0	2	
Clay and Rock		2	20	
Cemented Rock		20	60	
Gravel w/s Clay Stringer		60	120	
Cemented Rock w/s Gravel		120	160	

'92 MAR -9 P3:00
STATE ENGINEER'S OFFICE

Date started Jan. 12th, 1992
Date completed Jan 14th, 1992

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
15		

8. WELL CONSTRUCTION
Depth Drilled 160 Feet Depth Cased 160 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
8 3/4 Inches		0 Feet	160 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4 5/8		.188	0	160

Perforations:
Type perforation Factory
Size perforation 3/16
From 120 feet to 160 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50 Ft
Placement Method: ☐ Pumped ☒ Poured

Seal Type:
☐ Neat Cement
☐ Cement Grout
☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 160 feet to 50 feet

9. WATER LEVEL
Static water level 120 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name American Drilling Contractor
Address 3040 Callahan Rd. Contractor
Winnemucca, NV. 89445
Nevada contractor's license number issued by the State Contractor's Board 0020578
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 730
Signed Gerald Lee Moritz
By driller performing actual drilling on site or contractor
Date January 15th 1992

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627